



A P P R O V A L S ®

## Certificate of Approval

**Certificate No.:** SAA-171091-EA

**Certificate Holder:** Mean Well Enterprises Co., Ltd.  
No. 28, Wuquan 3rd Rd., Wugu Dist.,  
New Taipei City 248,  
Taiwan

**Class Description:** Power Supply or Charger  
**Product Description:** LED Controlgear  
(Independent SELV, Constant Voltage)

**Brand Name:** MEAN WELL

**Model No.:** IDLV-65-12

**Markings:** Input: 200-240V~ 50/60Hz 0.4A

Output: 12Vdc 4.2A 50.4W

ta:40°C tc:85°C, Class II

**Standard:** AS/NZS IEC 61347.2.13:2013

AS/NZS 61347.1:2016

**Conditions:** Nil

**Approval Mark:** SAA-171091-EA or RCM

**Date First Registered:** 6 June 2017

**Date of Expiry:** 6 June 2022


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 06-06-17 171091/1



A P P R O V A L S ®

# Certificate of Approval

## \* Addendum \*

**Certificate No.:** SAA-171091-EA

**Date of Issue:** 6 June 2017

**Class Description:** Power Supply or Charger  
**Product Description:** LED Controlgear  
(Independent SELV, Constant Voltage)

Additional Models	Description	Additional Models	Description
ODLV-65-12	Input: 200-240V~ 50/60Hz 0.4A Output: 12Vdc 4.2A 50.4W	ODLV-65-60	Input: 200-240V~ 50/60Hz 0.4A Output: 60Vdc 1.08A 64.8W
IDLV-65-24	Input: 200-240V~ 50/60Hz 0.4A Output: 24Vdc 2.4A 57.6W	IDLV-65A-12	Input: 200-240V~ 50/60Hz 0.4A Output: 12Vdc 4.2A 50.4W AUX: 0.6W + 12Vdc 50mA
ODLV-65-24	Input: 200-240V~ 50/60Hz 0.4A Output: 24Vdc 2.4A 57.6W	ODLV-65A-12	Input: 200-240V~ 50/60Hz 0.4A Output: 12Vdc 4.2A 50.4W AUX: 0.6W + 12Vdc 50mA
IDLV-65-36	Input: 200-240V~ 50/60Hz 0.4A Output: 36Vdc 1.8A 64.8W	IDLV-65A-24	Input: 200-240V~ 50/60Hz 0.4A Output: 24Vdc 2.4A 57.6W AUX: 0.6W + 12Vdc 50mA
ODLV-65-36	Input: 200-240V~ 50/60Hz 0.4A Output: 36Vdc 1.8A 64.8W	ODLV-65A-24	Input: 200-240V~ 50/60Hz 0.4A Output: 24Vdc 2.4A 57.6W AUX: 0.6W + 12Vdc 50mA
IDLV-65-48	Input: 200-240V~ 50/60Hz 0.4A Output: 48Vdc 1.35A 64.8W	IDLV-65A-36	Input: 200-240V~ 50/60Hz 0.4A Output: 36Vdc 1.8A 64.8W AUX: 0.6W + 12Vdc 50mA
ODLV-65-48	Input: 200-240V~ 50/60Hz 0.4A Output: 48Vdc 1.35A 64.8W	ODLV-65A-36	Input: 200-240V~ 50/60Hz 0.4A Output: 36Vdc 1.8A 64.8W AUX: 0.6W + 12Vdc 50mA
IDLV-65-60	Input: 200-240V~ 50/60Hz 0.4A Output: 60Vdc 1.08A 64.8W	IDLV-65A-48	Input: 200-240V~ 50/60Hz 0.4A Output: 48Vdc 1.35A 64.8W AUX: 0.6W + 12Vdc 50mA


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 06-06-17 171091/2



A P P R O V A L S ®

# Certificate of Approval

\* Addendum \*

**Certificate No.:** SAA-171091-EA

**Date of Issue:** 6 June 2017

**Class Description:** Power Supply or Charger

**Product Description:** LED Controlgear  
(Independent SELV, Constant Voltage)

Additional Models	Description	Additional Models	Description
ODLV-65A-48	Input: 200-240V~ 50/60Hz 0.4A Output: 48Vdc 1.35A 64.8W AUX: 0.6W + 12Vdc 50mA	ODLV-45-36	Input: 100-240V~ 50/60Hz 0.6A Output: 36Vdc, 1.0/1.25A, 36/45W
IDLV-65A-60	Input: 200-240V~ 50/60Hz 0.4A Output: 60Vdc 1.08A 64.8W AUX: 0.6W + 12Vdc 50mA	IDLV-45-48	Input: 100-240V~ 50/60Hz 0.6A Output: 48Vdc, 0.75/0.94A, 36/45.12W
ODLV-65A-60	Input: 200-240V~ 50/60Hz 0.4A Output: 60Vdc 1.08A 64.8W AUX: 0.6W + 12Vdc 50mA	ODLV-45-48	Input: 100-240V~ 50/60Hz 0.6A Output: 48Vdc, 0.75/0.94A, 36/45.12W
IDLV-45-12	Input: 100-240V~ 50/60Hz 0.6A Output: 12Vdc 3.0A 36W	IDLV-45-60	Input: 100-240V~ 50/60Hz 0.6A Output: 60Vdc, 0.6/0.75A, 36/45W
ODLV-45-12	Input: 100-240V~ 50/60Hz 0.6A Output: 12Vdc 3.0A 36W	ODLV-45-60	Input: 100-240V~ 50/60Hz 0.6A Output: 60Vdc, 0.6/0.75A, 36/45W
IDLV-45-24	Input: 100-240V~ 50/60Hz 0.6A Output: 24Vdc, 1.5/1.88A, 36/45.12W	IDLV-45A-12	Input: 100-240V~ 50/60Hz 0.6A Output: 12Vdc 3.0A 36W AUX: 0.6W + 12Vdc 50mA
ODLV-45-24	Input: 100-240V~ 50/60Hz 0.6A Output: 24Vdc, 1.5/1.88A, 36/45.12W	ODLV-45A-12	Input: 100-240V~ 50/60Hz 0.6A Output: 12Vdc 3.0A 36W AUX: 0.6W + 12Vdc 50mA
IDLV-45-36	Input: 100-240V~ 50/60Hz 0.6A Output: 36Vdc, 1.0/1.25A, 36/45W	IDLV-45A-24	Input: 100-240V~ 50/60Hz 0.6A Output: 24Vdc, 1.5/1.88A, 36/45.12W AUX: 0.6W + 12Vdc 50mA


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 06-06-17 171091/3



A P P R O V A L S ®

# Certificate of Approval

## \* Addendum \*

**Certificate No.:** SAA-171091-EA

**Date of Issue:** 6 June 2017

**Class Description:** Power Supply or Charger

**Product Description:** LED Controlgear  
(Independent SELV, Constant Voltage)

Additional Models	Description	Additional Models	Description
ODLV-45A-24	Input: 100-240V~ 50/60Hz 0.6A Output: 24Vdc, 1.5/1.88A, 36/45.12W AUX: 0.6W + 12Vdc 50mA	ODLV-45A-48	Input: 100-240V~ 50/60Hz 0.6A Output: 48Vdc, 0.75/0.94A, 36/45.12W AUX: 0.6W + 12Vdc 50mA
IDLV-45A-36	Input: 100-240V~ 50/60Hz 0.6A Output: 36Vdc, 1.0/1.25A, 36/45W AUX: 0.6W + 12Vdc 50mA	IDLV-45A-60	Input: 100-240V~ 50/60Hz 0.6A Output: 60Vdc, 0.6/0.75A, 36/45W AUX: 0.6W + 12Vdc 50mA
ODLV-45A-36	Input: 100-240V~ 50/60Hz 0.6A Output: 36Vdc, 1.0/1.25A, 36/45W AUX: 0.6W + 12Vdc 50mA	ODLV-45A-60	Input: 100-240V~ 50/60Hz 0.6A Output: 60Vdc, 0.6/0.75A, 36/45W AUX: 0.6W + 12Vdc 50mA
IDLV-45A-48	Input: 100-240V~ 50/60Hz 0.6A Output: 48Vdc, 0.75/0.94A, 36/45.12W AUX: 0.6W + 12Vdc 50mA		


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 06-06-17 171091/4