



MODEL : PB-300P-24

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	BOOST CHARGE VOLTAGE	28.8V ($\pm 0.3V$)	I/P: 230 VAC I/P: 115 VAC O/P:90% LOAD Ta:25°C	28.69 V/ 230 VAC 28.69 V/ 115 VAC	P
2	FLOAT CHARGE VOLTAGE	27.1V-27.3V	I/P: 230 VAC I/P: 115 VAC O/P: NO LOAD Ta:25°C	27.23 V/ 230 VAC 27.23 V/ 115 VAC	P
3	OUTPUT VOLTAGE ADJUST RANGE	CH1: 26V - 28.8V	I/P: 230 VAC I/P: 115 VAC O/P:NO LOAD Ta:25°C	25.08 V- 30.3 V/ 230 VAC 24.98 V- 30 V/ 115 VAC	P
4	MAX. OUTPUT CURRENT	10.5A	I/P : 230 VAC O/P : CHROMA C.V MODE=24V Ta : 25°C	10.5 A/ 230 VAC	P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	180VAC-264 VAC)	I/P:TESTING O/P: 90% LOAD Ta:25°C	138 V-264V	P
			I/P: LOW-LINE-3V= 177 V HIGH-LINE+15%=300 V O/P: 90% LOAD /MIN LOAD ON: 30 Sec . OFF: 30 Sec 10MIN (AC POWER ON/OFF NO DAMAGE)	TEST: OK	
2	INPUT FREQUENCY RANGE	47HZ -63 HZ NO DAMAGE OSC	I/P: 180VAC - 264 VAC O/P: 90% LOAD -MIN LOAD Ta:25°C	TEST: OK	P
3	POWER FACTOR	0.65 / 230 VAC (TYP)	I/P: 230 VAC O/P: 90% LOAD Ta:25°C	PF= 0.76 / 230 VAC	P
4	EFFICIENCY	86 % (TYP)	I/P: 230 VAC O/P: 90% LOAD Ta:25°C	88.7 %	P
5	INPUT CURRENT	230V/ 3 A (TYP) 115V/ 6 A(TYP)	I/P: 230 VAC I/P: 115 VAC O/P: 90% LOAD Ta:25°C	I = 1.8 A/ 230 VAC I = 4.6 A/ 115 VAC	P
6	INRUSH CURRENT	230V/ 60 A (TYP) COLD START	I/P: 230 VAC O/P: 90% LOAD Ta:25°C	I = 55 A/ 230 VAC	P
7	LEAKAGE CURRENT	< 3.5 mA / 240 VAC	I/P: 254 VAC O/P:Min LOAD Ta:25°C	L-FG: 1.1 mA N-FG: 1.1 mA	P

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	90 %- 110 %	I/P: 230 VAC I/P: 115 VAC O/P: TESTING Ta:25°C	100 %/ 230 VAC 100 %/ 115 VAC Constant Current Limiting	P
2	OVER VOLTAGE PROTECTION	CH1: 30V- 35V	I/P: 230 VAC I/P: 115 VAC O/P: MIN LOAD Ta:25°C	33.2 V/ 230 VAC 33.2 V/ 115 VAC Shunt down Re- power ON	P
3	OVER TEMPERATURE PROTECTION	Automatically derate charge current until zero	I/P: 230 VAC O/P: 90% LOAD	O.T.P. Active Automatically derate charge current until zero	P
4	REVERSE POLARITY	BY internal fuse	I/P: 230 VAC Ta:25°C	Fuse open	P

CONTROL FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	LED TEST	-----	I/P: 230 VAC O/P: TESTING	≤ 0.35 A LED: GREEN ≥ 0.4 A LED: RED	P
2	REMOTE CONTROL (CN5)	OPEN : Normal work Short : Stop charging	I/P: 230 VAC O/P: BAT 190AH Ta:25°C	OPEN : Normal work Short : Stop charging	P

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	TEMPERATURE RISE TEST	MODEL : PB-300P-12 1. HIGH AMBIENT BURN-IN : 15HRS I/P: 230VAC O/P: BAT 190AH CASE= 30.8 °C 2. HIGH AMBIENT BURN-IN : 7HRS I/P: 264VAC O/P: BAT 190AH CASE = 39.7 °C 3. HIGH AMBIENT BURN-IN : 15HRS I/P: 180VAC O/P: BAT 190AH CASE = 42.5 °C 4. HIGH AMBIENT BURN-IN : 7HRS I/P: 132VAC O/P: BAT 190AH CASE = 31.4 °C 5. HIGH AMBIENT BURN-IN : 17HRS I/P: 90VAC O/P: BAT 190AH CASE = 37 °C			P
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P: 230 VAC O/P: BAT 190AH CASE= -10 °C	TEST : OK	P
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 25°C NO DAMAGE	I/P: 272 VAC O/P: 90% LOAD Ta= 25°C HUMIDITY= 95 %R.H	TEST : OK	P
4	TEMPERATURE COEFFICIENT	± 0.05 %(0-50°C)	I/P: 230 VAC O/P: BAT 190AH	± 0.02 %(0-50°C)	P
5	VIBRATION TEST	1 Carton & 1 Set (1) Waveform: Sine Wave (2) Frequency: 10-500Hz (3) Sweep Time: 10min/sweep cycle (4) Acceleration: 2G (5) Test Time: 1 hour in each axis (X.Y.Z) (6) Ta: 25°C		TEST : OK	P

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P: 3 KVAC/min I/P-FG: 1.5 KVAC/min O/P-FG: 0.5 KVAC/min	I/P-O/P: 3.6 KVAC/min I/P-FG: 1.8 KVAC/min O/P-FG: 0.6 KVAC/min Ta:25°C	I/P-O/P: 11.04 mA I/P-FG: 9.38 mA O/P-FG: 12.89 mA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ I/P-FG: 500VDC>100MΩ O/P-FG:500VDC>100MΩ	I/P-O/P: 500 VDC I/P-FG: 500 VDC O/P-FG: 500 VDC Ta:25°C	I/P-O/P: 2 GΩ I/P-FG: 3 GΩ O/P-FG: 3 GΩ NO DAMAGE	P
3	GROUNDING CONTINUITY	FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40 A / 2min Ta:25°C	11 mΩ	P
4	APPROVAL	TUV: Certificate NO : UL: File NO : E183223			P

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	HARMONIC	EN61000-3-2 CLASS A	I/P: 230 VAC/50HZ O/P: 90% LOAD Ta:25°C	PASS	P
2	CONDUCTION	EN55022 CLASS B	I/P: 230 VAC (50HZ) O/P: 90% LOAD /50% LOAD Ta:25°C	PASS Test by certified Lab	P
3	RADIATION	EN55022 CLASS B	I/P: 230 VAC (50HZ) O/P: 90% LOAD Ta:25°C	PASS Test by certified Lab	P
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR:8KV / Contact:4KV	I/P: 230 VAC/50HZ O/P: 90% LOAD Ta:25°C	CRITERIA A	P
5	E.F.T	EN61000-4-4 LIGHT INDUSTRY INPUT: 1KV	I/P: 230 VAC/50HZ O/P: 90% LOAD Ta:25°C	CRITERIA A	P
6	SURGE	IEC61000-4-5 LIGHT INDUSTRY L-N :1KV L,N-PE:2KV	I/P: 230 VAC/50HZ O/P: 90% LOAD Ta:25°C	CRITERIA A	P
7	Test by certified Lab & Test Report Prepare				

M.T.B.F & LIFE CYCLE CALCULATION

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	CAPACITOR LIFE CYCLE	SUPPOSE C104 IS THE MOST CRITICAL COMPONENT I/P: 230VAC O/P: 90% LOAD CASE= 25 °C LIFE TIME= 1373958 HRS I/P: 230VAC O/P: 75% LOAD CASE= 50 °C LIFE TIME= 307095 HRS			P
2	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE: 115.8KHRS			P
3	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure : Above 30,000 hours @ TA 25°C			P



COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q 2 Rated 2SK2850 : 900V 6A	I/P:High-Line +3V = 267 V O/P: (1) 90% LOAD Turn on (2) 90% LOAD (3)Output Short Ta:25°C	(1) 820 V (2) 695 V (3) 810 V	P
2	Diode Peak Voltage	D102 Rated SF20LC30 : 300V 20 A	I/P:High-Line +3V = 267 V O/P: (1) 90% LOAD Turn on (2) 90% LOAD (3)Output Short Ta:25°C	(1) 219 V (2) 214 V (3) 224 V	P
3	Clamp Diode Peak Voltage	D2 Rated SF5408 : 1KV 3A	I/P:High-Line +3V = 267 V O/P: (1) 90% LOAD Ta:25°C	(1) 735 V	P
4	Input Capacitor Voltage	C5 Rated :470 u / 200V/105°C	I/P:High-Line +3V = 267 V O/P: (1) 90% LOAD Turn on /Off (2) Min load Turn on /Off (3) 90% /Min load Change (4)Burn in 1hour Ta:25°C	(1) 160 V (2) 173 V (3) 173 V (4) 160 V	P
5	Control IC Voltage Test	U1 Rated 3845 : 30V	I/P:High-Line +3V = 267 V O/P: (1) 90% LOAD Turn on /Off (2) Min load Turn on /Off (3) 90% /Min load Change Ta:25°C	(1) 19.4 V (2) 19.3 V (3) 19.4 V	P

DATE	SAMPLE	TEST RESULT	TESTER	APPROVAL
2005/11/30	RD SMAPLE	PASS	VINCENT TSENG	MAX LIN
2006/6/22	PRODUCT SAMPLE W0604B27	PASS	VINCENT TSENG	MAX LIN
2006/8/11	PRODUCT SAMPLE W0607B40	PASS	VINCENT TSENG	MAX LIN

2003/12/12 A50-F023