



Test Report : OWA-60U-12

60W Single Output Moistureproof Adaptor

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

Environment Test

■ DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	V1: 150 mVp-p (Max)	I/P: 230VAC O/P: 95% LOAD Ta: 25°C	V1: 92 mVp-p (Max)	PASS
2	OUTPUT VOLTAGE TOLERANCE	V1: -4%~ 4% (Max)	I/P: 100 VAC / 264 VAC O/P: 95%/ NO LOAD Ta: 25°C	V1: -0.58%~ 1.17%	PASS
3	LINE REGULATION	V1: -1%~ 1% (Max)	I/P: 100 VAC ~ 264 VAC O/P: 95% LOAD Ta: 25°C	V1: 0%~ 0%	PASS
4	LOAD REGULATION	V1: -1.5%~ 1.5% (Max)	I/P: 230 VAC O/P: 95%-NO LOAD Ta: 25°C	V1: -0.58%~ 0.66%	PASS
5	SET UP TIME	230VAC: 500 ms (Max) 115VAC: 1000 ms(Max)	I/P: 230 VAC I/P: 115 VAC O/P: 95% LOAD Ta: 25°C	230VAC/ 336 ms 115VAC/ 328 ms	PASS
6	RISE TIME	230VAC: 80 ms (Max) 115VAC: 80 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P: 95% LOAD Ta: 25°C	230VAC/ 33 ms 115VAC/ 35 ms	PASS
7	HOLD UP TIME	230VAC: 10 ms (TYP) 115VAC: 10 ms (TYP)	I/P: 230 VAC I/P: 115 VAC O/P: FULL LOAD Ta: 25°C	230VAC/ 110 ms 115VAC/ 24 ms	PASS
8	OVER/UNDERSHOOT TEST	< ±5%	I/P: 230 VAC O/P: 95% LOAD Ta: 25°C	TEST: < 5%	PASS
9	DYNAMIC LOAD	V1: 1200 mVp-p	I/P: 230 VAC (1) O/P: 95% /NO LOAD 90%DUTY/ 1KHZ (2) O/P: 95% /NO LOAD 50%DUTY/ 120HZ Ta: 25°C	(1) 432 mVp-p (2) 616 mVp-p	PASS
10	CONSTANT CURRENT REGION	V1 : 6 V ~ 12 V	I/P : 230VAC O/P : LED MODE Ta : 25°C	V1 : 5.0 V ~ 12 V	PASS

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	90VAC~264 VAC	I/P: TESTING O/P: 95% LOAD Ta: 25°C	87 V~264V	PASS
			I/P: (1)LOW-LINE-3V=87 V HIGH-LINE+15%=300 V O/P: 95%/NO LOAD ON: 30 Sec OFF: 30 Sec 10MIN (2)230Vac ON: 0.5 Sec OFF: 0.5 Sec 20MIN (3)230Vac ON: 3Sec OFF: 3Sec 12HOURS (POWER ON/OFF NO DAMAGE)	TEST: (1) OK (2) OK (3) OK	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE OSC	I/P: 90 VAC ~ 264 VAC O/P: 95% ~NO LOAD Ta: 25°C	TEST: OK	PASS
3	EFFICIENCY	88%/230VAC (TYP) 87%/115VAC (TYP)	I/P: 230 VAC I/P: 115 VAC O/P: 95% LOAD Ta: 25°C	89.08% /230VAC 88.26% /115VAC	PASS
4	INPUT CURRENT	230V/ 0.7A (TYP) 115V/ 1.2A (TYP)	I/P: 230 VAC I/P: 115 VAC O/P: 95% LOAD Ta: 25°C	I = 0.65 A/ 230 VAC I = 1.10 A/ 115 VAC	PASS
5	INRUSH CURRENT	230V/ 65A (TYP) 115V 35A (TYP) Twidth =750 us measured at 50% Ipeak COLD START	I/P: 230 VAC I/P: 115 VAC O/P: 95% LOAD Ta: 25°C	I = 53 A/ 230 VAC Twidth = 660 us I = 22.6 A/ 115 VAC Twidth = 680 us	PASS
6	LEAKAGE CURRENT	< 0.25 mA / 240 VAC	I/P: 240 VAC O/P: NO LOAD Ta: 25°C	L-CASE: 0.003 mA /240VAC N-CASE: 0.003 mA /240VAC	PASS
7	MIN LOAD POWER CONSUMPTION	< 0.15 W	I/P: 230 VAC I/P: 115 VAC O/P: NO LOAD Ta: 25°C	0.048W / 230VAC 0.038W / 115VAC	PASS

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	95 % ~ 108 %	I/P: 230 VAC I/P: 115 VAC O/P: TESTING Ta: 25°C	100.48 %/ 230 VAC 100.52 %/ 115 VAC Constant current limiting, recovers automatically after fault condition is removed	PASS
2	OVER VOLTAGE PROTECTION	CH1: 14 V ~ 16 V	I/P: 230 VAC I/P: 115 VAC O/P: NO LOAD Ta: 25°C	15.12 V/ 230 VAC 15.12 V/ 115 VAC Shut down o/p voltage, re-power on to recover	PASS
3	OVER TEMPERATURE PROTECTION	O.T.P NO DAMAGE	I/P: 230 VAC O/P: 95% LOAD	O.T.P Active Shut down o/p voltage, re-power on to recover	PASS
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P: 264 VAC O/P: 95% LOAD Ta: 25°C	NO DAMAGE Hiccup mode, recovers automatically after fault condition is removed	PASS

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated 650 V 15.5 A	I/P: High-Line +3V = 267 V O/P: (1) 95% LOAD Turn on (2) Output Short (3) 95% LOAD continue Ta: 25°C	(1) 572 V (2) 464 V (3) 478 V	PASS
2	Diode Peak Voltage	Q101 Rated 100 V 62 A	I/P: High-Line +3V = 267 V O/P: (1) 95% LOAD Turn on (2) Output Short (3) 95% LOAD continue Ta: 25°C	(1) 63.6 V (2) 58.0 V (3) 45.6 V	PASS
3	Input Capacitor Voltage	C5 Rated 150uF / 400 V	I/P: High-Line +3V = 267 V O/P: (1) 95% LOAD Turn on /Off (2) NO LOAD Turn on /Off (3) 95% LOAD /NO LOAD Change Ta: 25°C	(1) 382 V (2) 382 V (3) 380 V	PASS
4	Control IC Voltage Test	U1 Rated 28 V	I/P: High-Line +3V = 267 V O/P: (1) 95% LOAD Turn on /Off (2) NO LOAD Turn on /Off (3) 95% LOAD /NO LOAD Change Ta: 25°C	(1) 15.5 V (2) 15.5 V (3) 15.1 V	PASS

■ SAFETY & E.M.C. TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P: 3.75 KVAC/min	I/P-O/P: 4.2 KVAC/min Ta: 25°C	I/P-O/P: 2.255 mA NO DAMAGE	PASS
2	ISOLATION RESISTANCE	I/P-O/P: 500 VDC>100MΩ	I/P-O/P: 500 VDC Ta: 25°C /70%RH	I/P-O/P: >9999 MΩ NO DAMAGE	PASS

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	CONDUCTION	FCC Part15 CLASS B	I/P: 230 VAC/50HZ O/P: 95% LOAD Ta: 25°C	OK Test by certified Lab	PASS
2	RADIATION	FCC Part15 CLASS B	I/P: 230 VAC/50HZ O/P: 95% LOAD Ta: 25°C	OK Test by certified Lab	PASS
3	Test by certified Lab & Test Report Prepare				

■ RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT																																																																
1	TEMPERATURE RISE TEST	MODEL: OWA-60U-12 1. ROOM AMBIENT BURN-IN: 2 HRS I/P: 230VAC O/P: 95% LOAD Ta=27.1 °C 2. HIGH AMBIENT BURN-IN: 2 HRS I/P: 230VAC O/P: 95% LOAD Ta=50.8 °C			PASS																																																																
		<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>ROOM AMBIENT Ta= 27.1 °C</th> <th>HIGH AMBIENT Ta= 50.8 °C</th> </tr> </thead> <tbody> <tr><td>1</td><td>RTH1</td><td>60.1°C</td><td>75.9°C</td></tr> <tr><td>2</td><td>ZNR1</td><td>49.4°C</td><td>68.8°C</td></tr> <tr><td>3</td><td>LF2</td><td>49.1°C</td><td>70.8°C</td></tr> <tr><td>4</td><td>C5</td><td>52.6°C</td><td>74.3°C</td></tr> <tr><td>5</td><td>D5</td><td>60.8°C</td><td>83.4°C</td></tr> <tr><td>6</td><td>Q1</td><td>59.4°C</td><td>82.6°C</td></tr> <tr><td>7</td><td>U1</td><td>49.1°C</td><td>70.8°C</td></tr> <tr><td>8</td><td>C25</td><td>53.5°C</td><td>75.4°C</td></tr> <tr><td>9</td><td>T1</td><td>60.5°C</td><td>83.1°C</td></tr> <tr><td>10</td><td>Q101</td><td>60.3°C</td><td>83.6°C</td></tr> <tr><td>11</td><td>C205</td><td>55.7°C</td><td>77.9°C</td></tr> <tr><td>12</td><td>C105</td><td>58.4°C</td><td>80.8°C</td></tr> <tr><td>13</td><td>C106</td><td>59.0°C</td><td>81.8°C</td></tr> <tr><td>14</td><td>TSW1</td><td>50.9°C</td><td>72.6°C</td></tr> <tr><td>15</td><td>TC</td><td>51.2°C</td><td>73.7°C</td></tr> </tbody> </table>	NO	Position		ROOM AMBIENT Ta= 27.1 °C	HIGH AMBIENT Ta= 50.8 °C	1	RTH1	60.1°C	75.9°C	2	ZNR1	49.4°C	68.8°C	3	LF2	49.1°C	70.8°C	4	C5	52.6°C	74.3°C	5	D5	60.8°C	83.4°C	6	Q1	59.4°C	82.6°C	7	U1	49.1°C	70.8°C	8	C25	53.5°C	75.4°C	9	T1	60.5°C	83.1°C	10	Q101	60.3°C	83.6°C	11	C205	55.7°C	77.9°C	12	C105	58.4°C	80.8°C	13	C106	59.0°C	81.8°C	14	TSW1	50.9°C	72.6°C	15	TC	51.2°C	73.7°C		
NO	Position	ROOM AMBIENT Ta= 27.1 °C	HIGH AMBIENT Ta= 50.8 °C																																																																		
1	RTH1	60.1°C	75.9°C																																																																		
2	ZNR1	49.4°C	68.8°C																																																																		
3	LF2	49.1°C	70.8°C																																																																		
4	C5	52.6°C	74.3°C																																																																		
5	D5	60.8°C	83.4°C																																																																		
6	Q1	59.4°C	82.6°C																																																																		
7	U1	49.1°C	70.8°C																																																																		
8	C25	53.5°C	75.4°C																																																																		
9	T1	60.5°C	83.1°C																																																																		
10	Q101	60.3°C	83.6°C																																																																		
11	C205	55.7°C	77.9°C																																																																		
12	C105	58.4°C	80.8°C																																																																		
13	C106	59.0°C	81.8°C																																																																		
14	TSW1	50.9°C	72.6°C																																																																		
15	TC	51.2°C	73.7°C																																																																		
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P: 264VAC/100VAC O/P: 95% LOAD Ta= -40/-30°C	TEST: OK	PASS																																																																
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50 °C NO DAMAGE	I/P: 272 VAC O/P: 95% LOAD Ta= 50 °C HUMIDITY= 95 %R.H	TEST: OK	PASS																																																																
4	TEMPERATURE COEFFICIENT	±0.03 %(0~50°C)	I/P: 230 VAC O/P: 95% LOAD	±0.01 %(0~50°C)	PASS																																																																
5	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature: -45°C ~ +85°C 2. Temperature change rate: 25°C / MIN 3. Dwell time low and high temperature: 30 MIN/EACH 4. Total test cycle: 5 CYCLE 5. Input/Output condition: STATIC		OK	PASS																																																																
6	THERMAL SHOCK TEST	1. Thermal shock Temperature: -40°C ~ +55°C 2. Temperature change rate: 25°C / MIN 3. Dwell time low and high temperature: 30 MIN/EACH 4. Total test cycle: 10 CYCLE 5. Input/Output condition: 230VAC/95% LOAD AC ON/OFF TEST turn on 58sec; turn off 2sec		OK	PASS																																																																

7	VIBRATION TEST	1 Carton & 1 Set (1) Waveform: Sine Wave (2) Frequency: 10~500Hz (3) Sweep Time: 12min/sweep cycle (4) Acceleration: 5G (5) Test Time: 90min in each axis (X.Y.Z) (6) Ta: 25°C	TEST: OK	PASS
8	CAPACITOR LIFE CYCLE	OWA-60U-12: SUPPOSE C105 IS THE MOST CRITICAL COMPONENT (1) I/P: 230VAC O/P: 95% LOAD Ta=25 °C LIFE TIME (2) I/P: 230VAC O/P: 95% LOAD Ta=50 °C LIFE TIME (3) I/P: 230VAC O/P: 75% LOAD Ta=50 °C LIFE TIME (4) I/P: 230VAC O/P: 50% LOAD Ta=50 °C LIFE TIME	(1) 174715 HRS (2) 49174 HRS (3) 60468 HRS (4) 152126 HRS	PASS
9	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE: 292.8 KHRS		PASS
10	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure(Expected Life) : 50000 hours @ Tcase 70°C		PASS

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	ZHANGZJ/ZHUOKB	SKY	LIUWY

2009/08/04 A50-G058