

Report Date: 25/01/2019

Analysis Report: ST19-00564.001

ZHEJIANG FOTECH INTERNATIONAL CO., LTD
CHINA

The results shown in this test report specifically refer to the sample(s) tested as received unless otherwise stated. All tests have been performed using the latest revision of the methods indicated, unless specifically marked otherwise on the report. Precision parameters apply in the determination of the below results. Users of the data shown on this report should refer to the latest published revisions of ASTM D3244; IP 367 and ISO 4259 and when utilising the test data to determine conformance with any specification or process requirement. With respect to the UOP methods listed in the report below the user is referred to the method and the statement within it specifying that the precision statements were determined using UOP Method 999. This Test Report is issued under the Company's General Conditions of Service (copy available upon request or on the company website at www.sgs.com). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. This report shall not be reproduced except in full, without the written approval of the laboratory.

JOB ORDER NO. :	OPCNB1900048-01CG	BOSS ORDER NO.:	--
LOCATION :	Zhejiang, China.	PRODUCT DESCRIPTION :	Refrigerant - R407C
SAMPLE SOURCE :	Iso Tank	SOURCE ID :	TIFU 5257058
SAMPLE TYPE :	After Loading	SAMPLE BY :	SGS
SAMPLED :	16/01/2019	RECEIVED :	21/01/2019
ANALYSED :	25/01/2019	COMPLETED :	25/01/2019
CONTAINER:	1x500ml cylinder		
REPORT COMMENT :	The test report shall only be used for clients' scientific research, teaching, internal quality control, product research and development, etc... and just for internal reference.		

PROPERTY	METHOD	RESULT UNITS	MIN	MAX
R-32 Content	AHRI 700-2017 Appendix C Part 10	22.74 % (m/m)	21.0	25.0
R-125 Content	AHRI 700-2017 Appendix C Part 10	23.66 % (m/m)	23.0	27.0
R-134a Content	AHRI 700-2017 Appendix C Part 10	53.60 % (m/m)	50.0	54.0
Acidity (as HCl)	AHRI 700-2017 Appendix C Part 1	Not Detected mg/kg	--	1
Chloride	AHRI 700-2017 Appendix C Part 4	Pass ---	--	--
Non-Condensable Gas at 25°C	AHRI 700-2017 Appendix C Part 5	0.02 % (V/V)	--	1.5
Water	AHRI 700-2017 Appendix C Part 2	8 mg/kg	--	10
High Boiling Residue	AHRI 700-2017 Appendix C Part 3	<0.01 % (V/V)	--	0.01
Particulates/Solids	AHRI 700-2017 Appendix C Part 3	Pass ---	--	--

----- End of Analytical Results -----

REPORTED BY

Kevin Yang
Chemist

2501201909320000110700

AUTHORISED SIGNATORY

Demin Wang
Lab Manager

Page 1 of 1

No.88 Puguang Road, Shanghai Chemical Industry Park, Shanghai, China, 201507

OGC-EN_Report_60e-2017-07-11_v60e