

LT-4201TM/4301TM Hardware Manual



The information provided in this documentation contains general descriptions and/or technical characteristics of the performance of the products contained herein. This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the duty of any such user or integrator to perform the appropriate and complete risk analysis, evaluation and testing of the products with respect to the relevant specific application or use thereof. Neither Pro-face nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information that is contained herein. If you have any suggestions for improvements or amendments or have found errors in this publication, please notify us.

No part of this document may be reproduced in any form or by any means, electronic or mechanical, including photocopying, without express written permission of Proface.

All pertinent state, regional, and local safety regulations must be observed when installing and using this product. For reasons of safety and to help ensure compliance with documented system data, only the manufacturer should perform repairs to components.

When devices are used for applications with technical safety requirements, the relevant instructions must be followed.

Failure to use Pro-face software or approved software with our hardware products may result in injury, harm, or improper operating results.

Failure to observe this information can result in injury or equipment damage.

Copyright © 2013.05 Digital Electronics Corporation. All Rights Reserved.

Table of Contents



Package Contents. 14 Parts Identification and Functions. 16 System Architecture 16 Certifications and Standards. 27 Devices Overview 27 Chapter 2 LT System General Rules for Implementing 27 Installation Requirements 28 Environmental Characteristics. 23 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 33 Grounding the System. 34 Chapter 3 LT Description. 43.1 Rear Module Features. Clock. 44 3.1 Rear Module Features. Clock. 44 3.1 Rear Module Features. Clock. 44 3.1 Rever Connectivity Output Management 44 Output Management 44 Output Management 45 Interface Accessories 55 Chapter 5 LT Installation 51 Mechanical Requirements. 55 Dimensions 55 Panel Cut-Out Dimensions and Installation. </th <th></th> <th>Safety Information</th>		Safety Information
Chapter 1 LT General Overview 13 Package Contents. 14 Parts Identification and Functions. 14 Parts Identification and Functions. 16 System Architecture 16 Certifications and Standards. 22 Devices Overview. 22 Chapter 2 LT System General Rules for Implementing 25 Introduction 26 Installation Requirements. 22 Environmental Characteristics. 33 Wiring Rules and Recommendations. 35 Wiring to the DIO Terminal Block. 37 Grounding the System. 36 Chapter 3 LT Description. 3.1 Rear Module Features. 44 Clock. 44 3.2 I/O Management 44 Mut Management 44 Output Management 44 Output Management 45 Nut Management 46 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements. 56 Dimensi	Part I	LT System
Package Contents. 14 Parts Identification and Functions. 16 System Architecture 16 Certifications and Standards. 22 Devices Overview 22 Chapter 2 LT System General Rules for Implementing 22 Introduction 26 Installation Requirements 25 Environmental Characteristics. 31 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 37 Grounding the System. 36 Chapter 3 LT Description. 3.1 Rear Module Features. 44 Clock. 44 3.2 I/O Management 44 Output Management 44 Output Management 45 Interface Accessories 55 Chapter 5 LT Installation 55 System Design 55 Panel Cut-Out Dimensions and Installation. 66 Mounting Positions 66 Mounting Clearances 77 Din Rail. 77 Installing and Removing the Rear Module on a DIN Rail.	Chapter 1	
Parts Identification and Functions. 16 System Architecture 16 Certifications and Standards. 20 Devices Overview 22 Chapter 2 LT System General Rules for Implementing 25 Introduction 26 Installation Requirements 25 Environmental Characteristics. 33 Wiring to the DIO Terminal Block 33 Grounding the System. 36 Chapter 3 LT Description. 3.1 Rear Module Features. 44 Clock. 44 3.2 I/O Management 44 Input Management 44 Output Management 44 System Design 50 Interface Accessories 55 Chapter 5 LT Installation System Design 50 Interface Accessories 55 Softmensions 57 Panel Cut-Out Dimensions and Installation. 66 Mounting Positions 66 Mounting Clearances 77 DIN Rail. 77 Installing and Removing the R		
Certifications and Standards 20 Devices Overview 22 Chapter 2 LT System General Rules for Implementing 25 Introduction 26 Installation Requirements 26 Environmental Characteristics. 31 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 37 Grounding the System. 36 Chapter 3 LT Description. 42		
Certifications and Standards 20 Devices Overview 22 Chapter 2 LT System General Rules for Implementing 25 Introduction 26 Installation Requirements 26 Environmental Characteristics. 31 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 37 Grounding the System. 36 Chapter 3 LT Description. 42		System Architecture
Chapter 2 LT System General Rules for Implementing 25 Introduction 26 Installation Requirements 26 Environmental Characteristics. 31 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 37 Grounding the System. 35 Chapter 3 LT Description. 3.1 Rear Module Features. Clock. 44 3.2 I/O Management Muth Management 44 Output Management 44 Output Management 45 System Design 50 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements. 56 Dimensions . 57 51 Panel Cut-Out Dimensions and Installation. 61 Installation Procedures 64 Mounting Clearances 77 Din Rail. 72 Installation Procedures 64 Mounting Clearances 76 Din Rail. 77 Installing and		
Introduction 26 Installation Requirements 22 Environmental Characteristics 31 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 33 Grounding the System 34 3.1 Rear Module Features 44 Clock 44 3.1 Rear Module Features 44 Clock 44 3.2 I/O Management 44 Output Management 44 Output Management 44 Output Management 45 Interface Accessories 55 Chapter 4 Device Connectivity 49 System Design 56 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 57 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 64 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail <td< th=""><th></th><th></th></td<>		
Introduction 24 Installation Requirements 25 Environmental Characteristics 37 Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 37 Grounding the System 38 Chapter 3 LT Description 42 3.1 Rear Module Features 44 Clock 44 44 3.1 Rear Module Features 44 Clock 44 44 1.2 I/O Management 44 Output Management 44 Output Management 44 Dupt Management 44 System Design 56 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 57 Panel Cut-Out Dimensions and Installation 66 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 74 <tr< th=""><th>Chapter 2</th><th>LT System General Rules for Implementing</th></tr<>	Chapter 2	LT System General Rules for Implementing
Environmental Characteristics. 31 Wiring Rules and Recommendations 32 Wiring to the DIO Terminal Block 37 Grounding the System. 38 Chapter 3 LT Description	-	
Wiring Rules and Recommendations 33 Wiring to the DIO Terminal Block 37 Grounding the System 36 Chapter 3 LT Description 43 3.1 Rear Module Features. 44 Clock 44 3.2 I/O Management 45 Input Management 46 Output Management 47 Chapter 4 Device Connectivity 49 System Design 50 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements. 56 Dimensions 57 Panel Cut-Out Dimensions and Installation. 67 DIN Rail 72 Installation Procedures 66 Mounting Clearances 70 70 72 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 76 Owner Supply Characteristics and Wiring 76 76 Owner Supply Characteristics and Wiring 76 76 Sub Port 76		Installation Requirements
Wiring to the DIO Terminal Block 37 Grounding the System. 38 Chapter 3 LT Description. 43 3.1 Rear Module Features. 44 Clock 44 3.2 I/O Management 44 Input Management 44 Output Management 44 Output Management 45 System Design 50 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 9 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 64 Mounting Positions 66 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 75 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 76 Connecting the Power Supply 86 5.3 USB Port 86 Syst		Environmental Characteristics
Grounding the System. 33 Chapter 3 LT Description. 43 3.1 Rear Module Features. 44 Clock. 44 3.2 I/O Management . 45 Input Management . 46 Output Management . 47 Chapter 4 Device Connectivity . 49 System Design . 50 Interface Accessories . 50 Chapter 5 LT Installation . 50 Dimensions . 57 Panel Cut-Out Dimensions and Installation . 61 Installation Procedures . 64 Mounting Positions . 62 Mounting Clearances . 70 DIN Rail . 72 Installing and Removing the Rear Module on a DIN Rail . 73 5.2 Electrical Requirements . 76 Power Supply Characteristics and Wiring . 76 Connecting the Power Cord . 76 Connecting the Power Supply . 86 5.3 USB Port . 86 USB Data Transfer Cable - USB Driver Installation . 86		
Chapter 3 LT Description. 43 3.1 Rear Module Features. 44 Clock 44 3.2 I/O Management 44 Input Management 44 Output Management 44 Output Management 44 Chapter 4 Device Connectivity 45 System Design 50 Interface Accessories 55 Chapter 5 LT Installation 55 Solution Requirements. 56 Dimensions 57 Panel Cut-Out Dimensions and Installation. 67 Installation Procedures 64 Mounting Positions 64 Mounting Clearances 70 DIN Rail. 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 74 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 86 5.3 USB Port 86 USB Data Transfer Cable - USB Driver Installation 86		
3.1 Rear Module Features. 44 Clock 44 3.2 I/O Management 44 Input Management 44 Output Management 44 Output Management 44 Chapter 4 Device Connectivity 45 System Design 50 Interface Accessories 55 Chapter 5 LT Installation 55 5.1 Mechanical Requirements. 56 Dimensions 57 9 Panel Cut-Out Dimensions and Installation. 67 Installation Procedures 64 Mounting Positions 66 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 72 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 76 Connecting the Power Supply 86 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 85	-	
Clock	Chapter 3	
3.2 I/O Management 48 Input Management 46 Output Management 47 Chapter 4 Device Connectivity 49 System Design 50 Interface Accessories 53 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 57 Panel Cut-Out Dimensions and Installation 64 Mounting Positions 64 Mounting Positions 64 Mounting Resitions 64 Mounting Resitions 64 Mounting Positions 64 Mounting Resitions 64 Mounting Positions 64 Mounting Positions 64 Mounting Positions 64 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 74 Connecting the Power Cord 74 Connecting the Power Cord 74 S.3 USB Port 84	3.1	Rear Module Features
Input Management 44 Output Management 47 Chapter 4 Device Connectivity 49 System Design 50 Interface Accessories 53 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 62 Mounting Positions 62 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 74 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83		
Output Management 47 Chapter 4 Device Connectivity 49 System Design 50 Interface Accessories 53 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 64 Mounting Positions 62 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83	3.2	
Chapter 4 Device Connectivity 49 System Design 50 Interface Accessories 53 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 64 Mounting Positions 62 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83		
System Design 50 Interface Accessories 53 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 64 Mounting Positions 62 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83		
Interface Accessories 53 Chapter 5 LT Installation 55 5.1 Mechanical Requirements 56 Dimensions 57 Panel Cut-Out Dimensions and Installation 61 Installation Procedures 64 Mounting Positions 62 Mounting Clearances 70 DIN Rail 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83	Chapter 4	
Chapter 5 LT Installation 55 5.1 Mechanical Requirements. 56 Dimensions 57 Panel Cut-Out Dimensions and Installation. 61 Installation Procedures 64 Mounting Positions 62 Mounting Clearances 70 DIN Rail. 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 Power Supply Characteristics and Wiring. 76 Connecting the Power Cord 78 Connecting the Power Supply. 80 5.3 USB Port. 82 USB Data Transfer Cable - USB Driver Installation 83		· ·
5.1 Mechanical Requirements. 56 Dimensions 57 Panel Cut-Out Dimensions and Installation. 61 Installation Procedures 64 Mounting Positions 62 Mounting Clearances 70 DIN Rail. 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 76 Power Supply Characteristics and Wiring. 76 Connecting the Power Cord 78 Connecting the Power Supply. 80 5.3 USB Port. 82 USB Data Transfer Cable - USB Driver Installation 83		
Dimensions57Panel Cut-Out Dimensions and Installation61Installation Procedures64Mounting Positions62Mounting Clearances70DIN Rail72Installing and Removing the Rear Module on a DIN Rail735.2Electrical Requirements75Power Supply Characteristics and Wiring76Connecting the Power Cord78Connecting the Power Supply805.3USB Port82USB Data Transfer Cable - USB Driver Installation83	Chapter 5	
Panel Cut-Out Dimensions and Installation. 61 Installation Procedures 64 Mounting Positions 65 Mounting Clearances 70 DIN Rail. 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 75 Power Supply Characteristics and Wiring. 76 Connecting the Power Cord 78 Connecting the Power Supply. 80 5.3 USB Port. 82 USB Data Transfer Cable - USB Driver Installation 83	5.1	Mechanical Requirements
Installation Procedures64Mounting Positions69Mounting Clearances70DIN Rail72Installing and Removing the Rear Module on a DIN Rail735.2Electrical Requirements75Power Supply Characteristics and Wiring76Connecting the Power Cord78Connecting the Power Supply805.3USB Port82USB Data Transfer Cable - USB Driver Installation83		
Mounting Positions69Mounting Clearances70DIN Rail72Installing and Removing the Rear Module on a DIN Rail735.2Electrical Requirements75Power Supply Characteristics and Wiring76Connecting the Power Cord78Connecting the Power Supply805.3USB Port82USB Data Transfer Cable - USB Driver Installation83		
Mounting Clearances 70 DIN Rail. 72 Installing and Removing the Rear Module on a DIN Rail 73 5.2 Electrical Requirements 75 Power Supply Characteristics and Wiring. 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port. 82 USB Data Transfer Cable - USB Driver Installation 83		
DIN Rail72Installing and Removing the Rear Module on a DIN Rail735.2Electrical Requirements75Power Supply Characteristics and Wiring76Connecting the Power Cord78Connecting the Power Supply805.3USB Port82USB Data Transfer Cable - USB Driver Installation83		
Installing and Removing the Rear Module on a DIN Rail735.2Electrical Requirements75Power Supply Characteristics and Wiring76Connecting the Power Cord76Connecting the Power Supply805.3USB Port82USB Data Transfer Cable - USB Driver Installation83		•
5.2 Electrical Requirements 75 Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83		
Power Supply Characteristics and Wiring 76 Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83	5.0	
Connecting the Power Cord 78 Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83	5.2	•
Connecting the Power Supply 80 5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83		
5.3 USB Port 82 USB Data Transfer Cable - USB Driver Installation 83		
USB Data Transfer Cable - USB Driver Installation	5.2	
	5.5	
USB (Type A)		USB (Type A)
USB (mini-B)		

Part II Chapter 6	LT Unit and Display Modules	89 91
•	Presentation	92
	Digital Inputs	94
	Digital Outputs	96
Chapter 7	LT-4201TM/4301TM (Modular Type Analog)	99
	Presentation.	100
	Digital Inputs	102
	Digital Outputs	104
	Analog Inputs and Analog Outputs	107
Chapter 8	Display Modules	111
	Panel Overview	111
Part III	LT Controller Panels	115
Chapter 9	Communication Interface	117
•	Presentation.	118
	Ethernet Interface	118
	Serial Interface (COM1)	120
Chapter 10	Specifications	123
- 10.1	General Specifications	124
	General Specifications	124
10.2	Functional Specifications	125
	Display	126
	Digital Inputs	127
	Digital Outputs	129
	Analog Inputs and Analog Outputs	131
	Internal Circuits	135
	Memory and Touch Panel	137
Chapter 11	Maintenance	139
	Regular Cleaning	140
	Periodic Check Points	141

Safety Information



Important Information

NOTICE

Read these instructions carefully, and look at the equipment to become familiar with the device before trying to install, operate, or maintain it. The following special messages may appear throughout this documentation or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



The addition of this symbol to a Danger safety label indicates that an electrical hazard exists, which will result in personal injury if the instructions are not followed.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.

DANGER

DANGER indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury.

WARNING

WARNING indicates a potentially hazardous situation which, if not avoided, **can result in** death or serious injury.

CAUTION indicates a potentially hazardous situation which, if not avoided, **can** result in minor or moderate injury.

NOTICE

NOTICE is used to address practices not related to physical injury.

PLEASE NOTE

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Pro-face for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction and operation of electrical equipment and its installation, and has received safety training to recognize and avoid the hazards involved.

About the Book



At a Glance	
	Thank you for purchasing Pro-face's LT4000 Series Graphic Logic Controller Interface (Hereafter referred to as the "LT").
Document Scope	 The purpose of this document is to: Show you how to install and operate your LT. Show you how to connect the LT to a programming device equipped with GP-Pro EX. Help you understand how to interface the LT and other devices. Help you become familiar with the LT features.
Global Code	
	A global code is assigned to every Pro-face product as a universal model number.
	For more information on product models and their matching global codes, please refer to the following URL:
	http://www.pro-face.com/product/globalcode.html
Validity Note	
	This documentation is valid for GP-Pro EX V3.12 or later.
	The characteristics presented in this manual should be the same as those that appear online. In line with our policy of constant improvement we may revise content over time to improve clarity and accuracy. In the event that you see a difference between the manual and online information, use the online information as your reference.

Related Documents

Title of Documentation	
GP-Pro EX Reference Manual Maintenance/Troubleshooting Guide	
GP-Pro EX Device/PLC Connection Manual	

You can download these technical publications and other technical information from our website "Otasuke Pro!" at http://www.pro-face.com/otasuke/.

Product Related Information

\Lambda \Lambda DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Disconnect all power from all equipment including connected devices prior to removing any covers or doors, or installing or removing any accessories, hardware, cables, or wires except under the specific conditions specified in the appropriate hardware guide for this equipment.
- Always use a properly rated voltage sensing device to confirm the power is off where and when indicated.
- Replace and secure all covers, accessories, hardware, cables, and wires and confirm that a proper ground connection exists before applying power to the unit.
- Use only the specified voltage when operating this equipment and any associated products.

Failure to follow these instructions will result in death or serious injury.

This equipment has been designed to operate outside of any hazardous location. Only install this equipment in zones known to be free of a hazardous atmosphere.

POTENTIAL FOR EXPLOSION

Install and use this equipment in non-hazardous locations only.

Failure to follow these instructions will result in death or serious injury.

LOSS OF CONTROL

- Consider the potential failure modes of control paths in the machine control system design, such as:
 - The possibility of backlight failure,
 - Unanticipated link transmission delays or failures,
 - The operator being unable to control the machine,
 - The operator making errors in the control of the machine.
- Design outside the LT operations such as emergency stop, safety circuits, interlocks that operate with opposing actions such as clockwise/counterclockwise rotation, and circuits that prevent machine damage with positioning limits on top, bottom, and movement.
- For important operations handled by swiches, design your system to use a separate hardware device. This is to reduce the occurrence of incorrect outputs or malfunctions.
- Observe all accident prevention regulations and local safety guidelines.¹
- Test individually and thoroughly each implementation of the equipment for correct operation before service.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

¹ For additional information, refer to NEMA ICS 1.1 (latest edition), "Safety Guidelines for the Application, Installation, and Maintenance of Solid State Control" and to NEMA ICS 7.1 (latest edition), "Safety Standards for Construction and Guide for Selection, Installation and Operation of Adjustable-Speed Drive Systems" or their equivalent governing your particular location.

WARNING

UNINTENDED EQUIPMENT OPERATION

- Only use software approved by Pro-face for use with this equipment.
- Check your application program every time you change the physical hardware configuration, and make updates as required.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

LT System

Overview

This part describes how to use LT system.

What Is in This Part?

This part contains the following chapters:

Chapter	Chapter Name Page	
1	LT General Overview	13
2	LT System General Rules for Implementing	25
3	LT Description	43
4	Device Connectivity	49
5	LT Installation	55

LT General Overview

1

Overview

This chapter provides general information about the LT system architecture and its components.

What Is in This Chapter?


This chapter contains the following topics:

Торіс	
Package Contents	14
Parts Identification and Functions	
System Architecture	
Certifications and Standards	
Devices Overview	

Package Contents

LT Package Contents


Verify that all items shown in the figure are present in your package:



11 Warning / Caution information

Display Module Package Contents


Verify that all items shown in the figure are present in your package:



- 1 Display module
- 2 Display installation nut (attached to the display module)
- 3 Anti-rotation tee
- 4 Warning / Caution information

Rear Module Package Contents

Verify that all items shown in the figure are present in your package:




- 4 I/O connector 6-pin x 2
- 5 USB clamp type A
- 6 LT-4201TM/4301TM Installation Guide
- 7 Warning / Caution information

Product Label Sticker


You can identify the product version (PV) and the revision level (RL) from the product label on the panel.

The following diagram is a representation of a typical label:




Parts Identification and Functions

LT-4201TM/4301TM Parts Identification



Part	Description	
А	Display module (see page 111)	
В	Rear module (see page 89)	
С	USB (type A) interface connector (USB1) (see page 82)	
D	USB (type mini B) interface connector (USB2)	
E1	I/O terminal block 1 (see page 92)	
E2	I/O terminal block 2 (see page 92)	
F	DC power supply connector (see page 76)	
G	Ethernet interface (see page 118)	
Н	Serial link (RS-232C/485) (see page 120)	
I	CANopen interface (under development)	
J	Yellow button lock	

Rear Module Parts Identification



Part	Description	
В	Rear module (see page 89)	
С	USB (type A) interface connector (USB1) (see page 82)	
D	USB (type mini B) interface connector (USB2)	
E1	I/O terminal block 1 (see page 92)	
E2	I/O terminal block 2 (see page 92)	
F	DC power supply connector (see page 76)	
G	Ethernet interface (see page 118)	
Н	Serial link (RS-232C/485) (see page 120)	
1	CANopen interface (under development)	
J	Yellow button lock	


System Architecture

Introduction

The LT system is a compact control system with the Panel and I/O embedded. The LT system offers an all-in-one solution for an optimized configuration and an expandable architecture.

Architecture Example

The following figure provides an example of the LT hardware environment:




LT System Architecture

Combine the following modules and cables to design a versatile and effective system.

- Rear module that provides the logic and HMI functions
- Display module that provides the display function (see page 111)
- Display module/rear module separation cable that enables you to install the rear and display modules separately.

The figure shows the components of the LT:



- 1 Display module
- 2 Rear module
- 3 Display module/rear module separation cable

Certifications and Standards

Introduction

Pro-face submitted this product for independent testing and qualification by third party listing agencies. These agencies have certified this product as meeting the following standards.

For information on Standards and Regulations, such as certified models and certificates, see the marking on the product or the following link: http://www.proface.com/worldwide.html

Agency Certifications for LT Unit

LT is manufactured in accordance with UL 508 and CSA C22.2 $n^\circ 142$ for Industrial Control Equipment.

For use on a flat surface of a Type 1, Type 4X (indoor use only) enclosure.

Hazardous Substances

The LT is a device for use in factory systems. When using the LT in a system, the system should comply with the following standards in regards to the installation environment and handling:

- WEEE, Directive 2002/96/EC
- RoHS, Directives 2011/65/EU
- RoHS China, Standard SJ/T 11363-2006

CE Markings

This product conforms to the necessary requirements of the following Directives for applying the CE label:

- 2006/95/EC Low Voltage Directive
- 2004/108/EC EMC Directive

This conformity is based on compliance with IEC61131-2.

ENVIRONMENTAL HAZARDS TO THE EQUIPMENT

- Allow the device to reach the surrounding air temperature, not exceeding 50°C (122°F), before turning the device on.
- Do not turn on the device if condensation has occurred inside the device. After it is completely dry again, the device may be turned on.
- Do not expose the device to direct sunlight.
- Do not obstruct the vents in the device casing.
- Remove any dust from the device before turning it on.
- Ensure that the cable installation fasteners are not damaged. Replace them, if necessary.
- Mount the device into an enclosure that meets the IP65 level of protection.

Failure to follow these instructions can result in injury or equipment damage.

KC Markings

<u>사용자안내문</u>

기 종 별	사 용 자 안 내 문
	이 기기는 업무용(A급) 전자파적합기기로서 판매자 또는 사용자는 이 점을 주의하시기 바라며, 가정외의 지역에서 사용하는 것을 목적 으로 합니다.

Devices Overview

Overview

LT has various features. This LT can service a wide range of applications.

The software configuration and programming is accomplished with GP-Pro EX and is described in the GP-Pro EX Reference Manual.

LT Range

Series	Model Names	Models	Digital Input	Digital Output	Analog Input	Analog Output	Screen Size
LT4000 Series	LT-4201TM (Modular Type DIO) (see page 91)	PFXLM4201TADDC PFXLM4201TADDK	20 Points Standard Input (2 Points	10 Points Standard Input and 2 Points Fast	None	None	3.5 in.
	LT-4301TM (Modular Type DIO) (see page 91)	PFXLM4301TADDC PFXLM4301TADDK	for Fast Input)	Outpu			5.7 in.
	LT-4000M (Modular Type DIO) (see page 91)	PFXLM4B01DDC PFXLM4B01DDK					No
	LT-4201TM (Modular Type Analog) (see page 99)PFXLM4201TADAC PFXLM4201TADAK12 Points Standard Input (2 Points for Fast Input)6 Points Standard Output and 2 Points for Fast Input)LT-4301TM (Modular Type Analog) (see page 99)PFXLM4301TADAC PFXLM4301TADAK12 Points Standard Output and 2 Points for Fast Input)	2 ch analog inputs (13-bit) and 2 ch analog inputs	2 ch analog outputs (12-bit)	3.5 in.			
		(16-bit) for Thermocouple		5.7 in.			
	LT-4000M (Modular Type Analog) (see page 99)	PFXLM4B01DAC PFXLM4B01DAK					No
	3.5 inch display module (see page 111)	PFXXM4200TP	No		1	1	3.5 in.
	5.7 inch display module <i>(see page 111)</i>	PFXXM4300TP	No				5.7 in.

Note: Fast Input and Fast Output are generic terms for the following functions. Fast Input: High-speed Counter Input and Pulse Catch Input Fast Output: Pulse Output, PWM Output and High-speed Counter Synchronize Output

Display Module/Rear Module Separation Cable Range

Reference	Cable Length	
PFXZXMADSM31 (see page 60)	3 m (9.84 ft.)	
PFXZXMADSM51 (see page 60)	5 m (14.40 ft.)	
NOTE: The outer diameter of the cable is 8 mm (0.13 in.). To assemble this product, you need 20 mm (0.78 in.) more space to bend the cable in the end of the rubber.		

Model Name Indication

The table presents the model name identification numbers:

Legend	Number/Letter	Description			
$\mathbf{PFXLM4} \underbrace{\bullet 0 \bullet TAD \bullet \bullet}_{A \ B \ C \ D \ E \ F \ G}$					
А	2	LT-4201TM (3.5-inch): QVGA (320 x 240 dots)			
	3	LT-4301TM (5.7-inch): QVGA (320 x 240 dots)			
	В	No display (rear module)			
В	01	RS-232C/RS-485			
С	Т	TFT color LCD			
D	A	Analog touch panel			
E	D	DC type power supply is used			
F	A	Analog I/O with Digital I/O			
	D	Digital I/O			
G	С	Source output type			
	К	Sink output type			

Key Features

Programming languages

The LT is supported by and programmed with the GP-Pro EX, which supports the following IEC61131-3 programming languages:

- IL: Instruction List
- LD: Ladder Diagram

Power Supply (see page 75)

The power supply of the LT is 24 Vdc.

Clock (see page 44) The LT includes a Clock (RTC).

Memory (see page 137)

Embedded Input/Output

The following embedded I/O types are available. The I/O you can use depends on the model in use.

LT Range (see page 22).

- Standard Input
- Fast Input
- Standard Output
- Fast Output
- Analog Input
- Temperature Input
- Analog Output

Communication Interface

3 types of communication interface are available:

- Ethernet interface
- USB interface
- Serial link interface

For more details, refer to the chapter Communication interface (see page 117).

LT System General Rules for Implementing

2

Overview

This chapter describes the installation requirements, wiring rules and recommen dations, and the environmental specifications of the controller.

What Is in This Chapter?

This chapter contains the following topics:

Торіс	Page
Introduction	26
Installation Requirements	29
Environmental Characteristics	31
Wiring Rules and Recommendations	33
Wiring to the DIO Terminal Block	37
Grounding the System	39

Introduction

Before You Begin

WARNING

UNGUARDED MACHINERY CAN CAUSE SERIOUS INJURY

- Do not use this controller and related software on equipment that does not have point-of-operation protection.
- Do not reach into machinery during operation.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The LT controller and related software is used to control various industrial processes. The type or model of automation equipment suitable for each application will vary depending on factors such as the control function required, degree of protection required, production methods, unusual conditions, government regulations, and so on, in some applications, more than one processor may be required, as when backup redundancy is needed.

Only the user can be aware of all the conditions and factors present during the setup, operation, and maintenance of the machine; therefore, only the user can determine the automation equipment and the related safeties and interlocks that can be properly used. When selecting automation and control equipment and related software for a particular application, the user should refer to the applicable local and national standards and regulations.

In some applications, additional operator protection such as point-of-operation guarding must be provided. This is necessary if the operator's hands and other parts of the body are free to enter pinch points or other hazardous areas and serious injury can occur. The LT controller and related software products alone cannot protect an operator from injury. For this reason, this equipment cannot be substituted for or take the place of point-of-operation protection. Ensure that appropriate safeties and mechanical/electrical interlocks related to point of operation protection have been installed and are operational before placing the equipment into service. All interlocks and safeties related to point-of-operation protection must be coordinated with the related automation equipment and software programming.

WARNING

UNINTENDED EQUIPMENT OPERATION

- Use appropriate safety interlocks where personnel and/or equipment hazards exist.
- Install and operate this equipment in an enclosure appropriately rated for its intended environment.
- Use the sensor and actuator power supplies only for supplying power to the sensors or actuators connected to the module.
- Power line and output circuits must be wired and fused in compliance with local and national regulatory requirements for the rated current and voltage of the particular equipment.
- Do not use this equipment in safety-critical machine functions.
- Do not disassemble, repair, or modify this equipment.
- Do not connect any wiring to unused connections, or to connections designated as Not Connected (N.C.).

Failure to follow these instructions can result in death, serious injury, or equipment damage.

NOTE: Coordination of safeties and mechanical/electrical interlocks for point-ofoperation protection is outside the scope of this document, and are not included in any wiring diagrams, installation examples, application examples, programming examples, or other representations that may be included in this and other related documents.

Start-Up and Test

Before using electrical control and automation equipment for regular operation after installation, the system should be given by a start-up test qualified personnel to verify correct operation of the equipment. It is important that the arrangements for such a check be made and that enough time is allowed to perform complete and satisfactory testing.

ACAUTION

EQUIPMENT OPERATION HAZARD

- Verify that all installation and set up procedures have been completed.
- Before operational tests are performed, remove all blocks or other temporary holding means used for shipment from all component devices.
- Remove tools, meters, and debris from equipment.

Failure to follow these instructions can result in injury or equipment damage.

Follow all start-up tests recommended in the equipment documentation. Store all equipment documentation for future references.

Verify that the completed system is free from all short circuits and grounds, except those grounds installed according to local and national regulations. If high-potential voltage testing is necessary, follow recommendations in equipment documentation to help prevent accidental equipment damage or injury.

Before energizing equipment:

- Remove tools, meters, and debris from equipment.
- Close the equipment enclosure door.
- Remove ground from incoming power lines.
- Perform all start-up tests recommended by the manufacturer.

Operation and Adjustments

There are hazards that can be encountered if this equipment is improperly operated or adjusted, regardless of the care exercised in the design and manufacture of equipment or in the selection and ratings of components. It may be possible to misadjust this equipment and thereby produce unintended consequences. Only those operational adjustments required by the operator should be accessible to the operator. Access to other controls should be restricted to prevent unauthorized changes in operating characteristics or machine behavior. Restrict access to such adjustments only to qualified personnel familiar with the machinery in use, and familiar with the instructions of equipment manufacturers for all of the electrical equipment employed. Use the instructions from the manufacturers as a guide for functional, electrical, or other like adjustments.

Installation Requirements

Before Starting

Read and understand this chapter before beginning the installation of your LT.

Disconnecting Power

All options and modules should be assembled and installed before installing the control system on a mounting rail, onto a mounting plate or in a panel. Remove the control system from its mounting rail, mounting plate or panel before disassembling the equipment.

A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Disconnect all power from all equipment including connected devices prior to removing any covers or doors, or installing or removing any accessories, hardware, cables, or wires except under the specific conditions specified in the appropriate hardware guide for this equipment.
- Always use a properly rated voltage sensing device to confirm the power is off where and when indicated.
- Replace and secure all covers, accessories, hardware, cables, and wires and confirm that a proper ground connection exists before applying power to the unit.
- Use only the specified voltage when operating this equipment and any associated products.

Failure to follow these instructions will result in death or serious injury.

Programming Considerations

UNINTENDED EQUIPMENT OPERATION

- Only use software approved by Pro-face for use with this equipment.
- Check your application program every time you change the physical hardware configuration, and make any updates as required.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Operating Environment

This equipment has been designed to operate outside of any hazardous location. Only install this equipment in zones known to be free of a hazardous atmosphere.

POTENTIAL FOR EXPLOSION

Install and use this equipment in non-hazardous locations only.

Failure to follow these instructions will result in death or serious injury.

UNINTENDED EQUIPMENT OPERATION

- Use appropriate safety interlocks where personnel and/or equipment hazards exist.
- Install and operate this equipment in an enclosure appropriately rated for its intended environment.
- Use the sensor and actuator power supplies only for supplying power to the sensors or actuators connected to the module.
- Power line and output circuits must be wired and fused in compliance with local and national regulatory requirements for the rated current and voltage of the particular equipment.
- Do not use this equipment in safety-critical machine functions.
- Do not disassemble, repair, or modify this equipment.
- Do not connect any wiring to unused connections, or to connections designated as Not Connected (N.C.).

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Environmental Characteristics

Enclosure Requirements

LT system components are designed as Zone B, Class A industrial equipment according to IEC/CISPR Publication 11. If they are used in environments other than those described in the standard, or in environments that do not meet the specifications in this manual, the ability to meet electromagnetic compatibility requirements in the presence of conducted and/or radiated interference may be reduced.

All LT system components meet European Community (CE) requirements for open equipment as defined by EN61131-2. You must install them in an enclosure designed for the specific environmental conditions and to minimize the possibility of unintended contact with hazardous voltages. Use a metal enclosure to improve the electromagnetic immunity of your LT system. Use enclosures with a keyed locking mechanism to minimize accidents.

Environmental Characteristics

LT meets CE requirements as indicated in the table below, and is intended for use in a Pollution Degree 2 industrial environment.

Characteristic	Specification		
Standard compliance	IEC61131-2		
Ambient operating	Horizontal installation	050°C (32122°F)	
temperature for the display module and the rear module	Vertical installation	040°C (32104°F)	
Storage temperature		- 2060°C (- 4140°F)	
Storage altitude		010,000 m (032,808 ft)	
Operating altitude		02,000 m (06,560 ft)	
Surrounding Air and Strage Humidity		585% w/o condensation (non-condensing, wet bulb temperature 39°C (102.2°F) or less)	
Degree of pollution	IEC60664	2	
Degree of protection	IEC61131-2	IP20 with protective covers in place	
Corrosive gases		Free of corrosive gases	
Dust		\leq 0.1 mg/m ³ (10 ⁻⁷ oz/ft ³) (non-conductive levels)	
Atmospheric pressu	re (Operating Altitude)	8001,114 hPa (2000 m (6,561 ft) or lower)	
Vibration resistance	Mounted on a DIN rail	3.5 mm (0.138 in.) fixed amplitude from 58.4 Hz 9.8 m/s ² (1 g _n) fixed acceleration from	
		8.4150 Hz	
	Mounted on a panel	3.5 mm (0.138 in.) fixed amplitude from 58.6 Hz	
		9.8 m/s ² (1 g _n) fixed acceleration from 8.6150 Hz	

The table below gives the general environmental characteristics:

Characteristic	Specification	
Mechanical shock resistance	Mounted on a DIN rail	147 m/s ² (15 g_n) for a duration of 11 ms
	Mounted on a panel	147 m/s ² (15 g_n) for a duration of 6 ms

Electromagnetic Susceptibility

The LT meets electromagnetic susceptibility specifications as indicated in the table:

Characteristic	Specification	Range
Electrostatic discharge	IEC/EN 61000-4-2	8 kV (air discharge) 6 kV (contact discharge)
Rediated radio frecuency electromagnetic fields	IEC/EN 61000-4-3	10 V/m (80 MHz3 GHz)
Fast transients / Burst noise	IEC/EN 61000-4-4	Power lines: 2 kV Digital I/O: 1 kV Relay outputs: 2 kV Ethernet line: 1 kV COM line: 1 kV CAN line: 1 kV
Surge immunity	IEC/EN 61000-4-5	Power supply: CM: 1 kV; DM: 0.5 kV Digital I/O: CM: 1 kV; DM: 0.5 kV Shielded cable: 1 kV CM = line-earth DM = line-line
Condacted disturbances induced by radio- frequency fields	IEC/EN 61000-4-6	10 Veff (0.1580 MHz)
Mains terminal disturbance voltage	EN 55011 (IEC/CISPR11)	150500 kHz, quasi peak 79 dB μ V
		500 kHz30 MHz, quasi peak 73 dB μ V
Electric field strength	EN 55011 (IEC/CISPR11)	30230 MHz, quasi peak 10 m@40 dBµV/m
		230 MHz1 GHz, quasi peak 10 m@47 dBµV/m

Wiring Rules and Recommendations

Introduction

There are several rules that must be followed when wiring the LT.

Wiring Guidelines

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Disconnect all power from all equipment including connected devices prior to removing any covers or doors, or installing or removing any accessories, hardware, cables, or wires except under the specific conditions specified in the appropriate hardware guide for this equipment.
- Always use a properly rated voltage sensing device to confirm the power is off where and when indicated.
- Replace and secure all covers, accessories, hardware, cables, and wires and confirm that a proper ground connection exists before applying power to the unit.
- Use only the specified voltage when operating this equipment and any associated products.

Failure to follow these instructions will result in death or serious injury.

The following rules must be applied when wiring a LT:

- Input/Output and communication wiring must be kept separate from the power wiring. Route these 2 types of wiring in separate cable ducting.
- Verify that the operating conditions and environment are within specification.
- Use proper wire sizes to meet voltage and current requirements.
- Use copper conductors.
- Use twisted-pair, shielded cables for analog, and/or fast Input/Output.
- Use twisted-pair, shielded cables for networks, and fieldbus.
- For the power connector, refer to DC power supply wiring diagram (see page 77).
- When terminals A2 and B2 (signal name: Q1, Q0) are wired to external I/O, use the same power source for external I/O and the LT. Refer to Power Supply Connections (see page 81).
- If you use a temperature sensor with thermocouple inputs, make sure you use the compensation cable.
- Prevent temperature changes to the thermocouple connection terminal. Correct temperature measurement may not be possible if the thermocouple cold junction (LT's thermocouple compensation wiring to the connection terminal) experiences temperature changes.

IMPROPER GROUNDING CAN CAUSE UNINTENDED EQUIPMENT OPERA TION

- Use cables with insulated shielded jackets for analog Input/Output, fast Input/Output and communication signals.
- Ground shielded cables for analog Input/Output, fast Input/Output and communication signals at a single point ¹.
- Always comply with local wiring requirements regarding grounding of shielded cable.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

¹Multipoint grounding is permissible if connections are made to an equipotential ground plane dimensioned to help avoid shielded cable damage in the event of power system short circuit currents.

For more details, refer to Grounding Shielded Cables (see page 39).

The wire to use with the removable terminal blocks is 0.20 to 0.81 \mbox{mm}^2 (AWG 24 to 18).

DANGER

FIRE HAZARD

Use only the recommended wire sizes for I/O channels and power supplies.

Failure to follow these instructions will result in death or serious injury.

Terminal Block

Not plugging the terminal block into rear module correctly can cause an electric shock or unintended operation of the application and/or can damage the rear module.

A DANGER


UNINTENDED EQUIPMENT OPERATION OR ELECTRIC SHOCK

Be sure to connect the terminal blocks to their designated location.

Failure to follow these instructions will result in death or serious injury.

NOTE: To help prevent a terminal block from being inserted incorrectly, clearly and uniquely code and label each terminal block and rear module.

Avoid temperature changes on the thermocouple's connection terminal. Temperature measurements may not be accurate due to temperature changes in the cold junction (LT connection terminal for the thermocouple compensation cable). The figure shows the labels on each terminal block:



NOTE: Appearance of the connectors are the same but are different. Check the label and pin position of each connector before connecting.

Protecting Outputs from Inductive Load Damage


Depending on the load, a protection circuit may be needed for the outputs on the controllers and certain modules. Inductive loads using DC voltages may create voltage reflections resulting in overshoot that will damage or shorten the life of output devices

OUTPUT CIRCUIT DAMAGE DUE TO INDUCTIVE LOADS


Use an appropriate external protective circuit or device to reduce the risk of inductive direct current load damage.

Failure to follow these instructions can result in injury or equipment damage.

Protective circuit A: this protection circuit can be used for DC load power circuits and source outputs (positive logic).




Protective circuit A: this protection circuit can be used for DC load power circuits and sink outputs (negative logic).




- C represents a value from 0.1 to 1 μF.
- R represents a resistor of approximately the same resistance value as the load.

Protective circuit B: this protection circuit can be used for DC load power circuits and source outputs (positive logic).




Protective circuit B: this protection circuit can be used for DC load power circuits and sink outputs (negative logic).




Use a diode with the following ratings:

- Reverse withstand voltage: power voltage of the load circuit x 10.
- Forward current: more than the load current.

Protective circuit C: this protection circuit can be used for DC load power circuits and source outputs (positive logic).



Protective circuit C: this protection circuit can be used for DC load power circuits and sink outputs (negative logic).



• In applications where the inductive load is switched on and off frequently and/or rapidly, ensure that the continuous energy rating (J) of the varistor exceeds the peak load energy by 20% or more.

Wiring to the DIO Terminal Block

Introduction

Wiring Rules and Recommendations (see page 33).

EQUIPMENT DAMAGE

Be sure to remove the terminal blocks from the equipment prior to wiring.

Failure to follow these instructions can result in injury or equipment damage.

Screwdriver Required to Wire Terminal Blocks

Recommended type: 1891348-1 (Tyco Electronics AMP)

If another manufacturer is used, be sure the part has the following dimensions:

- point depth: 1.5 mm (0.06 in.)
- point height: 2.4 mm (0.09 in.)


Point shape must be DIN5264A and meet standard DN EN60900.

Also, the screwdriver tip must be flat, as indicated, to access the narrow hole of the terminal block:



The terminal blocks are a spring clamp type.

Procedure



Use the following procedure to connect the wires to the terminal blocks:

Step	Action
1	Insert the screwdriver into the square-shaped hole. This will open the wire's round-shaped hole.
2	Hold the screwdriver and insert the wire into the wire's round-shaped hole.
3	Take out the screwdriver from the square-shaped hole. The round-shaped hole will then close, and the wire will be held securely in place.

NOTE: To remove the wire, reinsert the screwdriver into the square-shaped hole and when the wire's spring clamp releases, pull out the wire.

⁽¹⁾ Wire should be 0.20...0.81 mm² (AWG 24...18), with the end twisted. Applicable wire style are UL1015 and UL1007.

⁽²⁾ Strip 7.0 mm (0.28 in) of membrane from the wire. If too much membrane is removed, the ends may short against each other or against the terminals, which can create an electric short. If not enough membrane is removed, the wire may not make sufficient contact with the terminal.

Insert each wire completely into its opening. Improper insertion can lead to a loss of unit power or short circuit, either against the wire filaments or against the terminals, or to over heating of the wire and terminal.

⁽³⁾ Do not rotate the point of the screwdriver inside the square-shaped opening. It may damage the equipment.

IMPROPER WIRING PRACTICES CAN MAKE EQUIPMENT INOPERABLE

- Use only the specified wire sizes for I/O channels and power supplies.
- Prepare wires and make connections as specified in this documentation.
- Do not connect more than one wire per terminal block connector.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Grounding the System

Overview

To minimize the effects of electromagnetic interference, cables carrying the fast Input/Output, analog Input/Output, and Serial communication signals must be shielded.

IMPROPER GROUNDING CAN CAUSE UNINTENDED EQUIPMENT OPERA TION

- Use cables with insulated shielded jackets for analog Input/Output, fast Input/Output and communication signals.
- Ground shielded cables for analog Input/Output, fast Input/Output and communication signals at a single point ¹.
- Always comply with local wiring requirements regarding grounding of shielded cable.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

¹To avoid damage to the shielded cable when there is a short circuit in the power line, set up a multi-point frame ground (FG) each with the same electric potential.

The use of shielded cables requires compliance with the following wiring rules:

- When there is no protective earth ground, you can use metal conduit or cable duct shield as a part of the protective earth ground. The functional ground (FE) shield must attenuate electromagnetic interference and must be shielded the length of the cable. If the purpose is for both functional and protective grounding, as is often the case for communication cables, the cable must have continuous shielding.
- Wherever possible, keep cables carrying one type of signal separate from the cables carrying other types of signals or power.

Protective Earth Ground on the Backplane

For protective grounding, connect braided copper cable (that can withstand the maximum voltage/current allowed by the system) to the conductive backplane.

Functional Ground on the DIN Rail

The DIN rail for your LT is common with the functional ground plane and must be mounted on a conductive backplane.

UNINTENDED EQUIPMENT OPERATION

When connecting DIN rails, connect the DIN rails to functional ground (FE).

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Shielded Cables Connections

Cables carrying the fast Input/Output, analog Input/Output, and Serial communication signals must be shielded. The shielding must be securely connected to ground. The fast Input/Output and analog Input/Output shields may be connected either to the functional ground (FE) or to the protective earth ground (PE) of your LT.

A WARNING

ACCIDENTAL DISCONNECTION FROM PROTECTIVE GROUND (PE)

- Do not use the grounding bar to provide a protective earth ground (PE).
- Use the grounding bar only to provide a functional ground (FE).

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The shielding of the cables must be connected to the protective earth ground (PE).

HAZARD OF ELECTRIC SHOCK


Make sure that cables are securely connected to the protective earth ground (PE).

Failure to follow these instructions will result in death or serious injury.

NOTE: The functional ground of the Ethernet connection is internal.

Protective Earth Ground (PE)

The following shows the steps when using shield cables for grounding the LT power supply, Standard Input/Output, High-speed Input/Output, Analog Input/Output, Temperature Input, Communication cable so on.



NOTE: The shielding must be clamped securely to the conductive backplane to ensure a good contact.

Exclusive Grounding

Connect the frame ground (FG) terminal on the power plug to an exclusive ground. When supplying power to the LT unit, be sure to separate the input, output and power lines, as shown.





Common Grounding

If exclusive grounding is not possible, use a common grounding point. Use grounding resistance of 10 $\Omega\,$ or less, wire thickness of 2.6 mm or more, or your country's applicable standard for the grounding point.

Precautions:

- Do not use common grounding, since it can lead to accidents and machine breakdown.
- If the equipment does not function properly when grounded, disconnect the ground wire from the FG terminal.





Grounding Procedure

Step	Action
1	Check that the grounding resistance is less than 100 Ω . (Grounding resistance of 100 Ω or less, wire thickness of 1.6 mm or more, or your country's applicable standard.)
2	Create the connection point as close to the unit as possible, and make the wire as short as possible. When using a long grounding wire, replace the thin wire with a thicker wire, and place it in a duct.

NOTE: FG and SG terminals are internally connected in the LT. When connecting an external device to the LT using the SG terminal, be sure to check that no short-circuit loop is created when you setup the system.

LT Description

3

Overview

This chapter describes the LT features.

What Is in This Chapter?

This chapter contains the following sections:

Section	Торіс	Page
3.1	Rear Module Features	44
3.2	I/O Management	45

3.1 Rear Module Features

Clock

Overview

The LT has a clock.

Variations in operating conditions can cause a clock shift:

Ambient Temperature	Accuracy (30 days deviation)
0°C (32 °F)	-11 minutes
25°C (77 °F)	-2.51 minutes
50°C (122 °F)	-5.50.5 minutes

Battery for clock

The controller has one battery for the clock.

In the event of a power interruption, the backup battery retains the time and date for the controller.

The table describes the characteristics of the battery:

Use	In the event of a transient power outage, the battery powers the clock.
Duration of backup	At least 5 years at 25 $^\circ C$ max (77 $^\circ F).$ At higher temperatures, the duration of backup is reduced.

NOTE: Do not replace the LT unit's battery yourself. The LT uses a lithium battery for backing up its internal clock data and the battery may explode if it is replaced incorrectly. When replacement is required, please contact your local LT distributor.

I/O Management

What Is in This Section?

This section contains the following topics:

Торіс	Page
Input Management	46
Output Management	47

Input Management

Overview

LT is equipped with Standard Inputs and Fast Inputs. You can manage the input values using the software filter function that eliminates the input signal noise.

This section explains the filter concept using Fast Input as an example.High-speed Counter Input and Pulse Catch Input can be managed as Special Input and Output.

Filter Principle of Special I/O

The filter is designed to reduce the bouncing effect at the inputs. Setting a filter value allows the controller to ignore sudden changes of input levels caused by noise.

Input

The following timing diagram illustrates the filter effects:

Output Management

Introduction

The LT includes Standard outputs and fast outputs.

The following output functions are configurable on fast outputs:

- PWM Output
- Pulse Output
- High-speed Counter (Synchronize Output)

Fast Output Management Availability

The information refers to all LT with fast outputs:

Output Terminal	Function
Q0	Pulse Output/CH 0, PWM Output/CH 0, High-speed Counter (Synchronize Output)/CH 0
Q1	Pulse Output/CH 1, PWM Output/CH 1, High-speed Counter (Synchronize Output)/CH 1

Short-circuit or Over-Current on Outputs

There are two groups for the output's short circuit and over-current.

Group 1 (Fast Output) has a short-circuit protection circuit between the output and V-. Group 2 (Standard Output) does not have this circuit.

LT-4201TM (Modular Type DIO) and LT-4301TM (Modular Type DIO)

- Group 1: 2 points Fast Output (Q0 to Q1)
- Group 2: 10 points Standard Output (Q2 to Q11)

LT-4201TM (Modular Type Analog) and LT-4301TM (Modular Type Analog)

- Group 1: 2 points Fast Output (Q0 to Q1)
- Group 2: 6 points Standard Output (Q2 to Q7)

The table describes the errors:

If	then
you have a short-circuit at 0 V on Fast Output	
you have a short-circuit at 24 V on Fast Output	generated. For more details, refer to the GP- Pro EX Reference Manual.
the current crossing the Fast Output 2 is too high	

For more information on protecting outputs, refer to your controller wiring diagram and to the general wiring rules (see page 33).

The Standard outputs of this equipment do not have built-in reverse polarity protection. Incorrectly connecting polarity can permanently damage the output circuits or otherwise result in unintended operation of the equipment.

NOTICE

DAMAGE TO FAST OUTPUTS

- Ensure the use of adequate protection against short-circuits on the power supply to the fast outputs.
- Do not connect positive voltage to any of the DC fast outputs terminals.

Failure to follow these instructions can result in equipment damage.

UNINTENDED MACHINE START-UP

Inhibit the automatic rearming of outputs if this feature is an undesirable behavior for your machine or process.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Wiring Considerations

NOTE: Turn on the power of LT before turning on the power of external I/O. Otherwise, the wrong signal for Pulse Ouput, PWM Output and High-speed Counter (Synchronize Output) is output.

WARNING

UNINTENDED EQUIPMENT OPERATION

Be sure to wire the outputs correctly according to the wiring diagram.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Device Connectivity

4

Introduction

This chapter presents the equipment you can connect to the LT panel.

What Is in This Chapter?

This chapter contains the following topics:


Торіс	Page
System Design	50
Interface Accessories	53

System Design


Introduction

The following diagrams represent the main selection of equipment you can connect to the panels.


Edit Mode Peripherals



Run Mode Peripherals - USB Type A/Mini B Interface



Run Mode Peripherals - Serial Communication and Ethernet Communication



Interface Accessories

Serial Interface Items

Reference Name	Reference Number	Description
RJ45 RS-232C Cable (5m)	PFXZLMCBRJR21	Cable with loose wires at one end for RS-232C connection between various hosts and the LT.
RJ45 RS-485 Cable (5m)	PFXZLMCBRJR81	Cable with loose wires at one end for RS-485 connection between various hosts and the LT.

USB Host Interface

Reference Name	Reference Number	Description
USBTransfer Cable (2 m)	CA3 USBCB-01	Download project data created with the Screen Editor and Logic Program Software via the LT unit's USB I/F.
USB Cable (5 m)	FP-US00	Connects a USB printer (type B)
USB Front Cable (1 m)	CA5 USBEXT-01	Extension cable that attaches to USB (mini B) port of the LT
USB Transfer Cable (USB A/mini B) (1.8 m)	ZC9USCBMB1	Cable for transferring screen data from the PC (USB type A) to LT (USB mini B)
USB Panel-Mount Extension Cable (USB mini B) (1 m)	ZC9USEXMB1	Extension cable that attaches to USB (mini B) port of the LT
EZ Illuminated Switch	PFXZCCEUSG1	A unit of 5 illuminated switches with multiple color LED easily connected with LT via USB.
EZ Fingerprint Recognition Unit	PFXZCCEUSS1	Fingerprint recognition unit easily connected with LT via USB.

Software

Reference Name	Description
GP-Pro EX	GP-Pro EX is screen editing & logic programming software made by Digital Electronics Corporation. You can edit screens with simple operations.

Maintenance Options

Reference Name	Reference Number	Description
Installation Nut	PFXZGMNT1	Nut to install the display module (10 pcs/set).
Socket Wrench	PFXZGMSW1	Socket wrench to tighten and loosen the display installation nut.
Accessories Kit	PFXZGMAK1	Anti-rotation tee, USB cable clamp to prevent disconnection (Type A, Mini-B, for 1 port), 2 mm-high spacer to adjust installation panel thickness (1pcs/each).
DC Power Supply Connector	PFXZGMCNDC1	Connector to connect DC power supply cable (5 pcs/set).
DIO Connector for LT4000M	PFXZLMCNIO1	15-pin I/O connector (Connector A x 1, Connector B x 1) and 6-pin I/O connector (Connector C x 1, Connector D x 1). NOTE: Connector A and B are different and connector C and D are different.

Options Items

Reference Name	Reference Number	Description
Screen Protection	LT-4201TM: CA6-DFS4-01	Disposable, dirt-resistant sheet for the
Sheet	LT-4301TM: PFXZCBDS61	unit'screen(5 sheet/set) (hard type).

LT Installation

5

Overview

This chapter provides installation safety guidelines, device dimensions, mounting instructions, and environmental specifications.

What Is in This Chapter?

This chapter contains the following sections:

Section	Торіс	Page
5.1	Mechanical Requirements	56
5.2	Electrical Requirements	75
5.3	USB Port	82

5.1 Mechanical Requirements


What Is in This Section?

This section contains the following topics:


Торіс	Page
Dimensions	57
Panel Cut-Out Dimensions and Installation	61
Installation Procedures	64
Mounting Positions	69
Mounting Clearances	70
DIN Rail	72
Installing and Removing the Rear Module on a DIN Rail	73

Dimensions


3.5 Inches Display Module




5.7 Inches Display Module




Rear Module




3.5 Inches Display Module and Rear Module






5.7 Inches Display Module and Rear Module



Display Module/Rear Module Separation Cable



NOTE:


Use this display module/rear module separation cable when the rear module is installed on the rail:

- The outer diameter of the cable is 8 mm (0.31 in.).
- There are 2 types of cable: 3 m (9.84 ft) and 5 m (16.4 ft).
- To assemble this product, you need 20 mm (0.78 in.) more space to bend the cable in the end of the rubber.

Panel Cut-Out Dimensions and Installation

Inserting a Display Module Without an Anti-Rotation Tee

Create a panel cut-out and insert the display module into the panel from the front. The figure shows the panel cut-out:




Dimensions

Α	B (1)	B (2)
22.50 ^{0/-0.30} mm (0.88 ^{0/-0.01} in.)	1.56 mm (0.060.23 in.)	36 mm (0.110.23 in.)
(1) Steel sheet(2) Glass fiber reinforced plastics (minimum GF30)		

NOTE: Without the tee option, the display module supports a rotating torque of $2.5 \text{ N} \cdot \text{m}$ (22.12 lb-in).

Inserting a Display Module With an Anti-Rotation Tee

Create a panel cut-out and insert the display module into the panel from the front. The figure shows the panel cut-out for a LT using a tee:




Dimensions

C	D
30 ^{0/-0.20} mm	4 ^{0/-0.20} mm
(1.18 ^{0/-0.0007} in.)	(0.15 ^{0/-0.007} in.)

NOTE: With using the tee option, the display module supports a rotating torque of 6 N•m (53.10 lb-in).

Installing the Display module

The figure shows the assembly:




- (4) Anti-rotation tee

Installing the Display module with spacer

The spacer, supplied in the accessory kit PFXZGMAK1 (sold separately), allows mounting the product on a:

- steel sheet support with a thickness between 1 and 1.5 mm (0.039 in. and 0.059 in.)
- plastic support with a thickness between 1 and 3 mm (0.039 in. and 0.118 in.)
- glass fiber reinforced plastic with a thickness between 2 and 3 mm (0.078 in. and 0.118 in.)

The figure shows the assembly with the spacer:



- (3) Spacer
- (4) Display installation nut
- (5) Anti-rotation tee

Installation Procedures

Installing the LT


EXPLOSION HAZARD

- Do not connect or disconnect while circuit is live.
- Potential electrostatic charging hazard: wipe the front panel of the terminal with a damp cloth before turning ON.


Failure to follow these instructions can result in death, serious injury, or equipment damage.

There are 2 ways to install the LT.

Installing the LT on the panel:



Installing the rear module on a DIN rail with a display module/rear module separation cable:



LT Setup Procedure


Mount the unit in an enclosure that provides a clean, dry, robust, and controlled environment (IP65 enclosure or UL508 4x, if indoors). (see page 31)

Before installing the LT verify that:

- The installation panel or cabinet surface is flat (planarity tolerance: 0.5 mm (0.019 in.)), in good condition and has no jagged edges. Metal reinforcing strips may be attached to the inside of the panel, near the panel cut-out, to increase the rigidity.
- The panel is designed to avoid any induced vibration resonance on the rear module exceeding a punctual factor of 10 and avoids any induced permanent vibration resonance.


To reduce the resonance use the panel adaptor accessory.

- The ambient operating temperature and the ambient humidity are within their specified ranges (see page 31). (When installing the panel in a cabinet or enclosure, the ambient operation temperature is the internal temperature of the cabinet or enclosure.)
- The heat from surrounding equipment does not cause the unit to exceed its specified operating temperature (see page 31).
- When installing the display module in a vertical position (portrait view), the logo on the display face must be on the right side to keep the power connector at the top:




NOTE: For use in Pollution Degree 2 environments.


• The panel face is not inclined more than 30° when installing the unit in a slanted panel:



- The power plug is positioned vertically when the unit is vertically installed.
- The unit is at least 100 mm (3.94 in.) away from adjacent structures and other equipment for easier maintenance, operation, and improved ventilation:


_____ in.





Step	Action
1	Place the unit on a clean and level surface with the display panel facing downward.
2	 The support thickness depends on the material: Steel sheet: between 1.5 and 6 mm (0.059 in. and 0.236 in.) Plastic: between 3 and 6 mm (0.118 in. and 0.236 in.)
	If the thickness is between 1 and 1.5 mm (0.039 in. and 0.059 in.) for a steel sheet support or between 1 mm and 3 mm (0.039 in. and 0.118 in.) for plastic, use the spacer supplied in accessory kit PFXZGMAK1 (sold separately).
3	Create the correct sized holes required to install the unit, using the Panel Cut- Out Dimension and Installation <i>(see page 61)</i> .


Step	Action
4	Insert the display module (with the tee, if required) into the panel hole:
	Use a torque between 1.2 and 2 N·m (10.62 lb-in and 17.70 lb-in) to screw the
	nut with the tightening wrench.
5	Insert and push the rear module until it locks into place:
	Insert and push



Mounting Positions

Correct Mounting Position

The rear module must be mounted with steel sheet horizontally or vertically as shown in the following figure:




NOTE: Keep adequate spacing for proper ventilation to maintain an ambient temperature between $0...50 \ ^{\circ}C (32...122 \ ^{\circ}F)$ for horizontal installation and $0...40 \ ^{\circ}C (32...104 \ ^{\circ}F)$ for vertical installation.

Incorrect Mounting Position

The rear module should only be positioned as shown in the Correct Mounting Position (see page 69) figure to help ensure adequate air flow through the product.

The figures show incorrect mounting positions.



Mounting Clearances

UNINTENDED EQUIPMENT OPERATION

- Place devices dissipating the most heat at the top of the cabinet and ensure adequate ventilation.
- Avoid placing this equipment next to or above devices that might cause overheating.
- Install the equipment in a location providing the minimum clearances from all adjacent structures and equipment as directed in this document.
- Install all equipment in accordance with the specifications in the related documentation.

Failure to follow these instructions can result in death, serious injury, or equipment damage.


NOTE: Keep adequate spacing for proper ventilation to maintain an ambient temperature between 0...50 °C (32...122 °F) for horizontal installation and 0...40 °C (32...104 °F) for vertical installation.

Mounting and keeping LT ventilated

The rear module has been designed as an IP20 product and must be installed in an enclosure. The clearances must be respected when installing the product.

- Distance and separation between the rear module and the front installation panel.
- Distance between the rear module and wiring duct.
- Distance between the rear module and peripherals.

The figure shows the minimum make singular needed for the LT controller:





DIN Rail

Dimensions of the DIN Rail

You can mount the controller and its expansion parts on a DIN rail. A DIN rail can be attached to a smooth mounting surface or suspended from a EIA rack or a NEMA cabinet.

The DIN rail measures 35 mm (1.38 in.) high and 15 mm (0.59 in.) deep, as shown below.





Installing and Removing the Rear Module on a DIN Rail

Overview

This section describes how to install and remove the rear module on a DIN rail.

A WARNING


EXPLOSION HAZARD


- Do not connect or disconnect while circuit is live.
- Potential electrostatic charging hazard: wipe the front panel of the terminal with a damp cloth before turning ON.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Installing the Rear Module on a DIN Rail


The following procedure describes how to install the rear module on a DIN rail:





Removing the Rear Module from a DIN Rail

The following procedure describes how to remove the rear module from a DIN rail:



5.2 Electrical Requirements

What Is in This Section?

This section contains the following topics:

Торіс	Page
Power Supply Characteristics and Wiring	76
Connecting the Power Cord	78
Connecting the Power Supply	80

Power Supply Characteristics and Wiring

Overview

This section provides the wiring diagrams and the characteristics of the DC power supply.

Power Supply Voltage Range

If the specified voltage range is not maintained, outputs may not switch as expected. Use appropriate safety interlocks and voltage monitoring circuits.



FIRE HAZARD

Use only the recommended wire sizes for I/O channels and power supplies.

Failure to follow these instructions will result in death or serious injury.

UNINTENDED EQUIPMENT OPERATION


Do not exceed any of the rated values specified.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

DC Power Supply Characteristics

Reference		Specification			
Voltage	rated	24 Vdc 20.428.8 Vdc			
	range				
Power interruption	time	10 ms at 20.4 Vdc			
Maximum inrush c	urrent	30 A at 25 °C and at 28.8 Vdc			
Continuous output power	with display	LT-4000M (Modular Type DIO) and PFXXM4200TP (3.5 inch display module) : 9 W	LT-4000M (Modular Type Analog) and PFXXM4300TP (5.7 inch display module) : 13 W		
	without display	LT-4000M (Modular Type DIO): 7 W	LT-4000M (Modular Type Analog): 10 W		
Insulation Resistar	nce	500 Vdc, 10 M Ω or more			
Isolation between DC power supply and internal logic, I/O, and protective ground (PE)		500 Vdc for 1 minute			
Power supply reverse protection		Yes			

DC Power Supply Wiring Diagram



1 Use an external, slow-blow, 2 A type T fuse.

A DANGER

FIRE HAZARD

Use only the recommended wire sizes for I/O channels and power supplies.

Failure to follow these instructions will result in death or serious injury.

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Power Interruption

The Voltage Drop is variable depending upon the load to the power supply of the controller, but generally a minimum of 10 ms is maintained as specified by IEC standards.

LT enters power-down status when a momentary power interruption of the rated voltage continues for 10 ms or longer. When the LT enters power-down status, it stops all calculations, even if there are instructions that are not completed.

For example, when the LT enters power-down status while 100 words of data are being transferred by a FMOV instruction, the transfer stops midway. Consequently, design your program with consideration to power-down occurrences.

UNINTENDED EQUIPMENT OPERATION

- Individually monitor each source of power used in the LT system including input power supplies, output power supplies, and the power supply to the controller to allow appropriate system shutdown during power system interruptions.
- The inputs monitoring each of the power supply sources must be unfiltered inputs.

Connecting the Power Cord

Introduction

Follow these instructions when supplying power to the unit:


- When the frame ground (FG) terminal is connected, verify the wire is grounded. Not grounding the unit can result in excessive Electromagnetic Interference (EMI). Grounding is required to meet EMC level immunity.
- The shield ground (SG) and FG terminals are connected internally in the unit.
- Remove power before wiring to the power terminals of the unit.
- The unit uses 24 Vdc power. Using any other level of power can damage both the power supply and the unit.
- Since the unit is not equipped with a power switch, connect a power switch to the unit's power supply.
- Field wiring terminal marking for wire type (75°C (167F) copper conductors only).

Power Cord Preparation

Before using your power cord:

- Verify that the ground wire is the same gauge or heavier than the power wires.
- Do not use aluminum wires for the power cord for power supply.
- If the conductor end (individual) wires are not twisted correctly, the end wires may either short loop to each other or against an electrode. To avoid this, use D25CE/AZ5CE cable ends.
- Use wires that are 0.75 to 2.5 mm² (18 to 12 AWG) for the power cord, and twist the wire ends before attaching the terminals.
- The conductor type is solid or stranded wire.
- To reduce electromagnetic noise, make the power cord as short as possible.

Power Plug



Connection	Wire
+	24 Vdc
-	0 Vdc
FG	Grounded terminal connected to the unit chassis

Connecting the Power Cord

The table explains how to connect the power plug:

Step	Action
1	Confirm the power cord is not connected to the power supply.
2	Check the rated voltage and remove the "DC24V" sticker on the DC power supply connector.
3	Remove 10 mm (0.39 in.) of the vinyl membrane off the ends of the power code wores.
4	If using stranded wire, twist the ends. Tinning the ends with solder reduces risk of fraying and ensures good electrical transfer.
5	Push the Opening button with a small and flat screwdriver to open the desired pin hole.
6	Insert each pin terminal into its corresponding hole. Release the Opening button to clamp the pin in place.
	Opening Button
	DC Power Cord + $+$ $(24V) (0V)+$ $+$ $+$ FG
7	After inserting all three pins, insert the power plug into the power connector on the LT.

NOTE:

- Do not solder the wire directly to the power receptacle pin.
- The power supply cord must meet the specification shown above. Twist the power cords together, up to the power plug, for EMC compliance.
- Use field wiring terminal marking for wire type (75 °C (167 °F) copper conductors only).

Connecting the Power Supply

Precautions

- Use the power plug to connect the power cord to the power connector on the side of the rear module.
- Use a regulated power supply with a Class 2 power supply between the line and the ground.
- Do not bundle the power supply cord with, or keep close to, main circuit lines (high voltage, high current), or input/output signal lines.
- Connect a lightning surge absorber to handle power surges.

Excessive stress on the power connection or attempting to install a rear module with the power cables connected may disconnect, or cause damage, to the power connections. This can cause short circuits, fire, or unintended equipment operation.

A WARNING


SHORT CIRCUITS, FIRE, OR UNINTENDED EQUIPMENT OPERATION

Avoid excessive force on the power cable to prevent accidental disconnections:


- Securely attach power cables to the panel or cabinet.
- Secure the power plug of the rear module.
- Install and fasten the rear module on the installation panel or cabinet prior to connecting power supply and communication lines.

Power Supply Connections

For maintenance purposes, use the following connection diagram for the power supply connection. However, when terminals A2 and B2 (signal name: Q1, Q0) are wired to external I/O, use the same power source for external I/O and the LT.




When wiring terminals A2 and B2 (signal name: Q1, Q0) to external I/O.




NOTE:

When connector A2 and B2 (Signal Name: Q1, Q0) are wired to external I/O, turn
on the LT before turning on the external device. Otherwise the wrong signal for
Pulse Output, PWM Output and High-speed Counter (Synchronize Output) will be
output. When transferring a program that turns off or resets the LT, first turn off
the external device. When using a system with multiple power supplies, please
note there is also a power supply in the external device.



- Ground the surge absorber separately from the rear module.
- Select a surge absorber that has a maximum circuit voltage greater than the peak voltage of the power supply.

The diagram illustrates a lightning surge absorber connection:



5.3 USB Port

Overview

This section presents the USB port.

What Is in This Section?

This section contains the following topics:

Торіс	Page
USB Data Transfer Cable - USB Driver Installation	83
USB (Type A)	84
USB (mini-B)	86

USB Data Transfer Cable - USB Driver Installation

Important Information

Follow these instructions to avoid damage to the cable connector or the unit:

- Do not connect the USB data transfer cable until told to do so in the instructions.
- Insert the connector at the correct angle when connecting the USB data transfer cable to the PC or to the unit.
- Hold the connector, not the cable itself when disconnecting the cable.
- Use the port designated during installation. If the cable is unplugged from the port designated during installation and connected to a different port, the Operating System (OS) will not recognize the new port.
- Restart the PC and quit all resident applications before reinstalling the software if the installation does not complete successfully.

NOTE: For transfer methods, refer to the following manual: GP-Pro EX Reference Manual "Transferring project files via USB transfer cable".

USB Host Interface Characteristics


	USB (Type A) Interface	USB (mini-B) Interface
Connector	USB 2.0 (Type A) x 1	USB 2.0 (mini-B) x 1
Power Supply Voltage	5 Vdc ± 5%	-
Maximum Current Supplied	500 mA	_
Maximum Transmission Distance	5 m (16.4 ft)	


USB (Type A)

Introduction


When using a USB device, you can attach a USB holder to the USB interface on the side of the unit to prevent the USB cable from being disconnected.


Attaching the USB Holder





Removing the USB Holder





- 1
- 2 USB cover
- 3 USB cable


USB (mini-B)

Introduction

When using a USB device, you can attach a USB holder to the USB interface on the unit to prevent the USB cable from being disconnected.


NOTE: The USB holder is supplied in the accessory kit PFXZGMAK1 (sold separately).

Attaching the USB Holder



Removing the USB Holder

Push down the tab of the USB holder and then remove the USB holder.



LT Unit and Display Modules

II

Overview

This part describes the LT Unit and the display modules.

What Is in This Part?

This part contains the following chapters:

Chapter	Chapter Name	Page
6	LT-4201TM/4301TM (Modular Type DIO)	91
7	LT-4201TM/4301TM (Modular Type Analog)	99
8	Display Modules	111

LT-4201TM/4301TM (Modular Type DIO)

6

Overview

This chapter describes the LT-4201TM/4301TM (Modular Type DIO).


What Is in This Chapter?

This chapter contains the following topics:


Торіс	Page
Presentation	92
Digital Inputs	94
Digital Outputs	96

Presentation

Terminal Blocks



The figure shows the pin assignment of the terminal blocks:



The table shows the group and signal names of the terminal blocks: **NOTE:** Confirm the connector label ABCD and the stamp ABCD on the unit before wiring.

Pin Arrangement	Group	Pin	Signal Name	Group	Pin	Signal Name
B1 OT OT A1 OT OT A1 OT OT A1 B6 OT A6	Fast Output	A1	V0+	Fast Output	B1	V0-
		A2	Q1		B2	Q0
	Standard	A3	V1+	Standard	B3	V1-
	Output	A4	V1+	Output	B4	V1-
		A5	Q3		B5	Q2
		A6	Q5		B6	Q4

The figure shows the terminal blocks:

Pin Arrangement	Group	Pin	Signal Name	Group	Pin	Signal Name
	Standard Output	C1	Q7	Standard Output	D1	Q6
		C2	Q9		D2	Q8
		C3	Q11		D3	Q10
	Fast Input/ Standard Input	C4	10	Fast Input/ Standard Input	D4	IC0
		C5	11	Standard Input	D5	12
	Standard Input	C6	13		D6	IC1
		C7	15		D7	14
		C8	17		D8	16
<u>OTFOTF</u>		C9	19		D9	18
		C10	IC2		D10	IC2
D15 OID OID C15		C11	111		D11	l10
		C12	113		D12	l12
		C13	115		D13	l14
		C14	117		D14	l16
		C15	119		D15	l18

The table shows the group and signal names of the terminal blocks:

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Disconnect all power from all equipment including connected devices prior to removing any covers or doors, or installing or removing any accessories, hardware, cables, or wires except under the specific conditions specified in the appropriate hardware guide for this equipment.
- Always use a properly rated voltage sensing device to confirm the power is off where and when indicated.
- Replace and secure all covers, accessories, hardware, cables, and wires and confirm that a proper ground connection exists before applying power to the unit.
- Use only the specified voltage when operating this equipment and any associated products.

Failure to follow these instructions will result in death or serious injury.

Digital Inputs

Overview

The rear module is equipped with 20 digital inputs.

FIRE HAZARD
Use only the recommended wire sizes for I/O channels and power supplies.
Failure to follow these instructions will result in death or serious injury.

Input Management Functions Availability


The table describes the possible usage of the rear module inputs:

E.m.o.t		Input Function				
Function Filtering Time		Standard Input	Fast Input	Counter Input		
		0.5 ms30.0 ms	None/4 µs/40 µs			
Fast	10	Х	Х	Х		
Input ¹	11	Х	Х	Х		
Digital	12	Х	-	_		
Input	13	Х	-	_		
	14	Х	-	_		
	15	Х	-	_		
	16	Х	-	_		
	17	Х	-	_		
	18	Х	-	_		
	19	Х	-	_		
	110	Х	-	_		
	11	Х	-	_		
	l12	Х	-	_		
	113	Х	-	_		
	114	Х	-	_		
	l15	Х	-	_		
	116	Х	-	_		
	117	Х	-	-		
	l18	Х	-	_		
	l19	Х	-	-		
X Yes - No 1 Can also	o be used	as a Standard input				

NOTE: You can use filters and functions to manage the LT's inputs.

Wiring Diagram

The figure describes the wiring diagram of the LTs digital inputs. Terminal Blocks (see page 92).



Fast Input/Standard Input:

UNINTENDED EQUIPMENT OPERATION

Do not connect wires to unused terminals or terminals marked "Not Connected (N.C.)".

Failure to follow these instructions can result in death, serious injury, or equipment damage.

UNINTENDED EQUIPMENT OPERATION

Use a single power source for the sensor and actuator.

Digital Outputs

Overview

The rear module is equipped with 10 transistor outputs that you can manage *(see page 47)*.



FIRE HAZARD

Use only the recommended wire sizes for I/O channels and power supplies. Failure to follow these instructions will result in death or serious injury.

Output Management Functions Availability

The table describes the possible usage of the rear module outputs:

		Output F	Output Function			
Function		Standard Output	Pulse Output/ PWM Output			
Fast	Q0	-	Х			
Output ¹	Q1	-	Х			
Digital	Q2	Х	-			
Output	Q3	Х	-			
	Q4	Х	_			
	Q5	Х	-			
	Q6	Х	-			
	Q7	Х	-			
	Q8	Х	-			
	Q9	Х	-			
	Q10	Х	_			
	Q11	Х	_			
X Yes - No						
	be used as a Standard output					

Fast Output Wiring Diagram

For additional information about fast output protection, refer to Protecting Outputs from Inductive Load Damage *(see page 35)*.




UNINTENDED EQUIPMENT OPERATION

Be sure to wire the outputs correctly according to the wiring diagram.

Wiring Diagram

The figure describes the wiring diagram of the LT's digital outputs: Terminal Blocks (see page 92).


NOTE: When terminals A2 and B2 (signal name: Q1, Q0) are wired to external I/O, use the same power source for external I/O and the LT. Refer to Power Supply Connections (see page 81).



Standad Input:


(1) When connecting as power surges

Pulse Output/PWM Output/High-speed Counter (Synchronize Output):



NOTE: Q0 and Q1 circuits are push-pull circuits. The following is the operation of the push-pull circuit at the Sink Output and the Source Output. Sink Output: +24(V) is output to terminal Q0, Q1 when the logic for Q0, Q1 is off Source Output: 0(V) is output to terminal Q0, Q1 when the logic for Q0, Q1 is off

Standard Output terminals Q2 or later are common open collector outputs. Do not connect Fast Output terminals Q0, Q1 and Standard Output terminals Q2 or later. It will short. If you add a manual circuit to terminal Q0, Q1, isolate the manual circuit and terminal Q0, Q1 with a relay. Without isolation, it will short.



UNINTENDED EQUIPMENT OPERATION

Do not connect wires to unused terminals or terminals marked "Not Connected (N.C.)".

LT-4201TM/4301TM (Modular Type Analog)

7

Overview

This chapter describes the LT-4201TM/4301TM (Modular Type Analog).


What Is in This Chapter?

This chapter contains the following topics:


Торіс	Page
Presentation	100
Digital Inputs	102
Digital Outputs	104
Analog Inputs and Analog Outputs	107

Presentation

Terminal Blocks



The figure shows the pin assignment of the terminal blocks:



The table shows the group and signal names of the terminal blocks: **NOTE:** Confirm the connector label ABCD and the stamp ABCD on the unit before wiring.

Pin Arrangement	Group	Pin	Signal Name	Group	Pin	Signal Name	
	Fast Output	A1	V0+	Fast Output	B1	V0-	
		A2	Q1		B2	Q0	
	Standard	A3	V1+	Standard	B3	V1-	
			A4	Q3	Output	B4	Q2
		A5	Q5		B5	Q4	
		A6	Q7		B6	Q6	

The figure shows the terminal blocks:

Pin Arrangement	Group	Pin	Signal Name	Group	Pin	Signal Name
	Fast Input/ Standard Input	C1	10	Fast Input/ Standard Input	D1	IC0
		C2	11	Standard Input	D2	l2
		C3	13		D3	IC1
	Standard Input	C4	15		D4	14
QIEQIE		C5	17	_	D5	16
D15 000 C15		C6	19		D6	18
		C7	l11		D7	l10
	Temperature Input	C8	MS0+	Temperature Input	D8	MS0-
		C9	EX0+		D9	EX0-
		C10	MS1+		D10	MS1-
		C11	EX1+		D11	EX1-
	Analog Input	C12	IV0	Analog Input	D12	AIC
		C13	IV1		D13	IA0
		C14	IA1	Analog Output	D14	AOC
	Analog Output	C15	U/I0		D15	U/I1

The figure shows the group and the signal name of the terminal blocks:

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Disconnect all power from all equipment including connected devices prior to removing any covers or doors, or installing or removing any accessories, hardware, cables, or wires except under the specific conditions specified in the appropriate hardware guide for this equipment.
- Always use a properly rated voltage sensing device to confirm the power is off where and when indicated.
- Replace and secure all covers, accessories, hardware, cables, and wires and confirm that a proper ground connection exists before applying power to the unit.
- Use only the specified voltage when operating this equipment and any associated products.

Failure to follow these instructions will result in death or serious injury.

Digital Inputs

Overview

The rear module is equipped with 12 digital inputs.



Input Management Functions Availability

The table describes the possible usage of the rear module inputs:


Function Filtering time		Input Function				
		Standard Input	Fast Input	Counter Input		
		0.5 ms30.0 ms	None/4 µs/40 µs			
Fast	10	Х	Х	X		
Input ¹	1	Х	Х	Х		
Digital	12	Х	-	_		
Input	13	Х	-	_		
	14	Х	-	_		
	15	Х	-	_		
	16	Х	-	_		
	17	Х	-	_		
	18	Х	-	-		
	19	Х	-	_		
	110	Х	-	_		
	11	Х	-	_		
X Yes - No	_		· /			
Can also	an also be used as a Standard input					


NOTE: You can use filters and functions to manage the LT's inputs.

Wiring Diagram

The figure describes the wiring diagram of the LTs digital inputs. Terminal Blocks (see page 100).

High-speed Input/Standard Input:





a Sink inputs (positive logic)

b Source inputs (negative logic)

UNINTENDED EQUIPMENT OPERATION

Do not connect wires to unused terminals or terminals marked "Not Connected (N.C.)".

Failure to follow these instructions can result in death, serious injury, or equipment damage.

A WARNING

UNINTENDED EQUIPMENT OPERATION

Use a single power source for the sensor and actuator.

Digital Outputs

Overview

The rear module is equipped with 6 transistor outputs that you can manage (see page 47).



FIRE HAZARD

Use only the recommended wire sizes for I/O channels and power supplies. Failure to follow these instructions will result in death or serious injury.

Output Management Functions Availability

The table describes the possible usage of the rear module outputs:

			Output Function			
	Function	า	Standard Output	Pulse Output/ PWM Output		
	Fast	Q0	-	Х		
	Output ¹	Q1	-	X		
	Digital	Q2	Х	-		
	Output	Q3	Х	-		
		Q4	Х	-		
		Q5	Х	-		
		Q6	Х	_		
		Q7	Х	-		
Х	Yes					
-	No					
1	Can also be used as a Standard output					

Fast Output Wiring Diagram

For additional information about fast output protection, refer to Protecting Outputs from Inductive Load Damage (see page 34).

WARNING

UNINTENDED EQUIPMENT OPERATION


Be sure to wire the outputs correctly according to the wiring diagram.

Wiring Diagram


The figure describes the wiring diagram of the LTs digital outputs. Terminal Blocks (see page 100).

Standard Input:

Source outputs (positive logic)




Sink outputs (negative logic)




(1) When connecting as power surges

Pulse Output/PWM Output/High-speed Counter (Synchronize Output):



NOTE: Q0 and Q1 circuits are push-pull circuits. The following is the operation of the push-pull circuit at the Sink Output and the Source Output. Sink Output: +24(V) is output to terminal Q0, Q1 when the logic for Q0, Q1 is off Source Output: 0(V) is output to terminal Q0, Q1 when the logic for Q0, Q1 is off

Standard Output terminals Q2 or later are common open collector outputs. Do not connect Fast Output terminals Q0, Q1 and Standard Output terminals Q2 or later. It will short. If you add a manual circuit to terminal Q0, Q1, isolate the manual circuit and terminal Q0, Q1 with a relay. Without isolation, it will short.



UNINTENDED EQUIPMENT OPERATION

Do not connect wires to unused terminals or terminals marked "Not Connected (N.C.)".

Analog Inputs and Analog Outputs

Overview

The rear module is equipped with:

- 2 ch Thermocouple/Temperature Probes (16-bit)
- 2 ch analog inputs (13-bit)
- 2 ch analog outputs (12-bit)

DANGER

FIRE HAZARD

Use only the recommended wire sizes for I/O channels and power supplies.

Failure to follow these instructions will result in death or serious injury.

A WARNING

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Analog Features

There are different terminal connection points for each type of analog signal.

Since current and voltage requires different adjustment values, you also need to configure the desired type of input or output signal:

- -10...10 Vdc voltage signal (default).
- 0...10 Vdc voltage signal
- 0...20 mA current signal.
- 4...20 mA current signal.


The temperature measurement values are converted into numeric values that can be processed by the controller. For temperature measurements, the temperature rear module returns the measured value in 0.1° C (0.18° F) steps.

The table shows the analog features:

Number and Type of Channels	Digital Resolution	Voltage/Current
2 ch inputs	13 bit	-1010 Vdc (digital value -4096 to 4095)/ 010 Vdc (digital value 0 to 8192) 020 mA (digital value 0 to 8192)/ 420 mA (digital value 0 to 8192)
2 ch inputs	16 bit	RTD (Resistance Temperature Detector): Pt100/Pt1000/Ni100/Ni1000 Thermocouple: J, K, R, B, S, T, E, N
2 ch outputs	12 bit	-1010 Vdc (digital value -2048 to 2047)/ 010 Vdc (digital value 0 to 4095) 020 mA (digital value 0 to 4095)/ 420 mA (digital value 0 to 4095)

Wiring Diagram

The figure describes the wiring diagram of the rear module analog inputs and analog outputs:



A WARNING

UNINTENDED EQUIPMENT OPERATION

Do not connect wires to unused terminals or terminals marked "Not Connected (N.C.)".

WARNING

IMPROPER GROUNDING CAN CAUSE UNINTENDED EQUIPMENT OPERA TION

- Use cables with insulated shielded jackets for analog Input/Output, fast Input/Output and communication signals.
- Ground shielded cables for analog Input/Output, fast Input/Output and communication signals at a single point ¹.
- Always comply with local wiring requirements regarding grounding of shielded cable.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

¹Multipoint grounding is permissible if connections are made to an equipotential ground plane dimensioned to help avoid shielded cable damage in the event of power system short circuit currents.

UNINTENDED EQUIPMENT OPERATION

- Use shielded cables wherever specified for inputs, outputs, and communication connections.
- Properly ground the cable shields as indicated in the related documentation.
- Route communication and I/O cables separately from power cables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

NOTICE

INOPERABLE EQUIPMENT

Be sure that the physical wiring of the analog circuit is compatible with the software configuration for the analog channel.

Failure to follow these instructions can result in equipment damage.

Display Modules



Panel Overview

Introduction

The LT is a Human Machine Interface product that has an operating voltage of 24 Vdc.

The table describes the LT characteristics:

Part Number	Screen Size	Screen (Pixel) Resolution	Color Definition	Display Type
LT-4201TM (Modular Type DIO)	3.5 in.	320 x 240 (QVGA)	65536 colors and LED backlight	TFT
LT-4201TM (Modular Type Analog)				
3.5 inch display module				
LT-4301TM (Modular Type DIO)	5.7 in.			
LT-4301TM (Modular Type Analog)				
5.7 inch display module				

Critical Systems, Detected Alarms and Handling Requirements

Critical detected alarm indicators and system functions require independent and redundant protection hardware and/or mechanical interlocks.

If the unit for any reason becomes inoperative (for example, an inoperative backlight) it may be difficult or impossible to identify operation. Operations that may present a hazard if not immediately executed, such as emergency stop, must be provided independently of the unit. The design of the control system must take into account an inoperative unit (backlight) and the operator may be is unable to control the machine or respond to detected errors with the unit.

After turning OFF the LT, be sure to wait at least 10 seconds before turning it ON again. The LT may not operate correctly if it is restarted too quickly.

LOSS OF CONTROL

- Consider the potential failure modes of control paths in the machine control system design, such as:
 - The possibility of backlight failure,
 - Unanticipated link transmission delays or failures,
 - The operator being unable to control the machine,
 - The operator making errors in the control of the machine.
- Design outside the LT operations such as emergency stop, safety circuits, interlocks that operate with opposing actions such as clockwise/counterclockwise rotation, and circuits that prevent machine damage with positioning limits on top, bottom. and movement.
- For important operations handled by switches, design your system to use a separate hardware device. This is to reduce the occurrence of incorrect outputs or malfunctions.
- Observe all accident prevention regulations and local safety guidelines.¹
- Test individually and thoroughly each implementation of the equipment for correct operation before service.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

¹ For additional information, refer to NEMA ICS 1.1 (latest edition), "Safety Guidelines for the Application, Installation, and Maintenance of Solid State Control" and to NEMA ICS 7.1 (latest edition), "Safety Standards for Construction and Guide for Selection, Installation and Operation of Adjustable-Speed Drive Systems" or their equivalent governing your particular location.

UNINTENDED EQUIPMENT OPERATION

- Do not use the LT as a control unit for system critical operations such as start/stop or output control of motors.
- Do not use the LT as the only warning device for critical alarms such as device overheat or device over-current.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Handling the LCD

The following characteristics are specific to the LCD and are considered normal behavior:

- LCD screen may show unevenness in the brightness of certain images or may appear different when seen from outside the specified viewing angle. Extended shadows, or cross-talk, may also appear on the sides of screen images.
- LCD screen pixels may contain black and white-colored spots and color display may seem to have changed over time.
- When the same image is displayed on the screen for a long period, an afterimage may appear when the image is changed. If this happens, turn off the unit, wait 10 seconds, and then restart it.

NOTE: Do not display the same image for a long time. Change the screen image periodically.

SERIOUS EYE AND SKIN INJURY

The liquid present in the LCD contains an irritant:

- Avoid direct skin contact with the liquid.
- Wear gloves when you handle a broken or leaking unit.
- Do not use sharp objects or tools in the vicinity of the LCD touch panel.
- Handle the Panel carefully to prevent puncture, bursting, or cracking of the Panel material.

Failure to follow these instructions can result in injury or equipment damage.

If the Panel is damaged and any liquid comes in contact with your skin, immediately rinse the area with running water for at least 15 min.

If the liquid gets in your eyes, immediately rinse your eyes with running water for at least 15 minutes and consult a doctor.

Using Touch Panel Correctly

UNINTENDED EQUIPMENT OPERATION

- Operate the touch panel with only one finger.
- Do not activate two or more points of the touch panel simultaneously.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Use only one finger to select an object on the touch panel.

If the touch panel receives pressure at two or more points at the same time, an unintended object could be selected.

LT Controller Panels



Overview

This part describes how to use LT controller panels.

What Is in This Part?

This part contains the following chapters:

Chapter	Chapter Name	Page
9	Communication Interface	117
10	Specifications	123
11	Maintenance	139

Communication Interface

9

What Is in This Chapter?

This chapter contains the following topics:

Торіс	Page
Presentation	118
Ethernet Interface	118
Serial Link Interface (COM1)	120


Presentation

Introduction

The LT is equipped with an IEEE802.3 compliant Ethernet interface that transmits and receives data at 10 Mbps or 100 Mbps.

Ethernet Interface

The figure shows the location of the RJ45 Ethernet interface on the rear module:



Do not confuse the RJ45 Ethernet interface with the RJ45 serial interface.

NOTE: When you use a 1:1 connection to connect to a device such as PC, you can use a cross cable, but we recommend using a hub.

Characteristics

The table describes the different Ethernet characteristics:

Characteristic	Description	
Connector type	RJ45	
Driver	 10 M half duplex (auto negotiation) 100 M full duplex (auto negotiation) 	
Cable type	Shielded	
Automatic cross-over detection	Yes	

Pin Assignment

The figure shows the RJ45 Ethernet connector pin assignment:



The table describes the RJ45 Ethernet connector pins:

Pin	Signal
1	TD+
2	TD-
3	RD+
4	-
5	-
6	RD-
7	-
8	-

NOTE: The LT supports the MDI/MDIX auto-crossover cable function. You do not have to use special Ethernet crossover cables to connect devices directly to this port (connections without an Ethernet hub or switch).

Status LEDs

The table describes the Ethernet LEDs operations:

Label	Description	LED			
		Color	Status	Description	
IND1 Ethernet status		Green	Off	No connection or subsequent transmission failure.	
			On	Data transmission is available	
IND2	Ethernet activity	Green	Off	No data transmission	
			On	Data transmission is occurring	

Serial Interface (COM1)


Introduction

The serial interface is used to communicate with devices supporting protocol as a master.

To enable communications through serial links, the LT includes an RS-232/485 serial interface.

Serial Port Connector

The figure shows the location of the RJ45 serial interface on the rear module:



Do not confuse the RJ45 serial interface with the RJ45 Ethernet interface.

RS-232C Characteristics

Characteristic		Description
Connector type		RJ45
Isolation		None
Maximum baud rate		115,200 bps
Cable	Туре	Shielded
Maximum length		15 m (49 ft)
5 Vdc power supply for RS-232C		None

NOTE: The maximum baud rate for the serial communication depends on the protocol used.

RS-485 Characteristics

Characteristic		Description	
Connector type		RJ45	
Isolation		None	
Maximum baud rate		115,200 bps	
Cable Type		Shielded	
	Maximum length	200 m (656 ft)	
Polarization		Setting is require via software when connecting Multiple LTs. Refer to the "GP-Pro EX Device/PLC Manual" for the setting.	
5 Vdc power supply for R	S-485	No	

Pin Assignment

The figure shows the pins of the RJ45 connector when viewed from LT:



The table describes the pin assignment of the RJ45 connector:

Pin	RS-232C	RS-485	Description
1	RxD	N.C.	Received data (RS-232C)
2	TxD	N.C.	Transmitted data (RS-232C)
3	N.C.	N.C.	Not connected
4	N.C.	D1+	Differential data (RS-485)
5	N.C.	D0-	Differential data (RS-485)
6	N.C.	N.C.	Not connected
7	N.C.	N.C.	Not connected
8	GND	GND	Signal ground

WARNING

UNINTENDED EQUIPMENT OPERATION

Do not connect wires to unused terminals or terminals marked "Not Connected (N.C.)".

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Specifications

10

Overview

This chapter presents the LT specifications.

What Is in This Chapter?

This chapter contains the following sections:

Section	Торіс	Page
10.1	General Specifications	124
10.2	Functional Specifications	125

10.1 General Specifications

General Specifications

Electrical Specifications

The table shows the electrical specifications of LT:

Part Number	Rated Input Voltage	Input Voltage Limits	Acceptable Voltage Drop	Power Consumption	In-Rush Current	Voltage Endurance between power terminal and frame ground (FG)	Insulation Resistance between power terminal and FG
LT-4201TM (Modular Type DIO)	24 Vdc	2028.8 Vdc	10 ms or less at 20.4 Vdc	9 W or less	30 A or less at 28.8 Vdc	500 Vdc for 1 minute	10 MΩ or higher at 500 Vdc
LT-4201TM (Modular Type Analog)	24 Vdc	2028.8 Vdc	10 ms or less at 20.4 Vdc	12 W or less	-	500 Vdc for 1 minute	10 MΩ or higher at 500 Vdc
LT-4301TM (Modular Type DIO)	24 Vdc	2028.8 Vdc	10 ms or less at 20.4 Vdc	10 W or less	-	500 Vdc for 1 minute	10 MΩ or higher at 500 Vdc
LT-4301TM (Modular Type Analog)	24 Vdc	2028.8 Vdc	10 ms or less at 20.4 Vdc	13 W or less		500 Vdc for 1 minute	10 MΩ or higher at 500 Vdc

Environmental Specifications

The table shows the environmental specifications of LT:

	Characteristic	Specification			
	Vibration immunity (operating)	IEC 61131-2			
	Protection structure	NEMA TYPE 4X (indoors, with panel e	mbedded)		
	Protection (front module)	IP65f - (IEC 60529)			
	Protection (rear module)	IP 20 - (IEC 60529)			
	Shock immunity (operating)	IEC 61131-2 15 gn 11 ms			
	Cooling method	Natural air circulation			
Environment	Weight	LT-4201TM (Modular Type DIO): 496 g (17.49 oz) LT-4301TM (Modular Type DIO): 749 g (26.41 oz)	LT-4201TM (Modular Type Analog): 531 g (18.73 oz) LT-4301TM (Modular Type Analog): 784 g (27.65 oz)		
Invir	Color	Front module: PT404Rear module: RAL 7032			
Mechanical E	Material	 front module: PC/PBT rear module: PC/PBT front module: PAA+GF rear module: PC/PBT 	 front module: PC/PBT rear module: PC/PBT front module: PAA+GF rear module: PC/PBT 		

10.2 Functional Specifications

Overview

This section presents the LT functional specifications of the display, memory, and $\ensuremath{\mathsf{I/O}}$.

What Is in This Section?

This section contains the following topics:

Торіс	Page
Display	126
Digital Inputs	127
Digital Outputs	129
Analog Inputs and Analog Outputs	131
Internal Circuits	135
Memory and Touch Panel	137

Display

Display Specifications

The table shows the display specifications of the LT:

Items	LT-4201TM		LT-4301TM
	3.5 inch Display Module		5.7 inch Display Module
Туре	TFT Color LCD		TFT Color LCD
Resolution (pixels)	320 x 240 (QVGA)		320 x 240 (QVGA)
Active display area (W x H)	70.56 x 52.92 mm (2.78 x 2.08 in.)		115.2 x 86.4 mm (4.53 x 3.40 in.)
Display Colors	65536 colors		65536 colors
Backlight	White LED		White LED
	Non-exchangeable		Non-exchangeable
	LED ON / OFF control, adjustable screen saver activation time		LED ON / OFF control, adjustable screen saver activation time
	Brightness adjustment 16 levels of adjustmen menu		available via touch panel in the configuration
Language Fonts ⁽¹⁾	Japanese, ASCII, Chinese (Simplified), Chinese (Traditional), Korean, Cyrillic, Thai		
Character sizes	8 x 8, 8 x 16, 16 x 16 and 32 x 32 pixel fonts		8 x 8, 8 x 16, 16 x 16 and 32 x 32 pixel fonts
Font sizes	Width can be expanded 18 times. Height can be expanded 1/2 and 18 times.		Width can be expanded 18 times. Height can be expanded 1/2 and 18 times.
8 x 8 pixels	40 characters per row x 30 rows		40 characters per row x 30 rows
8 x 16 pixels	40 characters per row x 15 rows		40 characters per row x 15 rows
16 x 16 pixels	20 characters per row x 15 rows		20 characters per row x 15 rows
32 x 32 pixels	10 characters per row x 7 rows		10 characters per row x 7 rows
(1) Please refer	to the GP-Pro EX Refere	nce Manual for details or	font types and character codes.

Digital Inputs

Digital Input Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the digital inputs:

Characteristic		Value	
Rated current		5 mA	
Inrush values	Voltage	30 Vdc	
	Current	6.29 mA max.	
Input impedance		4.9 kΩ	
Input type		Sink/Source	
Rated voltage		24 Vdc	
Maximum Allowable Voltage	Э	28.8 Vdc	
Input limit values	ON Voltage	15 Vdc or more (1528.8 Vdc)	
	OFF Voltage	5 Vdc or less (05 Vdc)	
	ON Current	2.5 mA or more	
	OFF Current	1.0 mA or less	
Isolation	Method	Photocoupler Isolation	
	Between internal logic	500 Vdc	
Filtering		0.5 ms30.0 ms	
IEC61131-2 3 type		Type 1	
Compatibility		Supports 2 wire and 3 wire sensors	
Cable type and length		Shielded: Maximum 100 m (328 ft) Non-shielded: 50 m (164 ft)	
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable	
Input paralleling		No	

High-speed Counter Input Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the High-speed Counter and Pulse Catch inputs:

Characteristic		Value	
Rated current Voltage		24 Vdc	
	Current	7.83 mA	
Inrush values	Voltage	30 Vdc	
	Current	9.99 mA	
Input impedance		3.2 kΩ	
Input type		Sink/Source	
Rated voltage		24 Vdc	
Maximum Allowable Vo	oltage	28.8 Vdc	
Input limit values	ON Voltage	15 Vdc or more	
	OFF Voltage	5 Vdc or less	
	ON Current	5 mA or more	
	OFF Current	1.5 mA or less	
Isolation	Method	Photo coupler Isolation	
	Between internal logic	500 Vdc	
Filtering		None, 4 μs, 40 μs	
IEC61131-2 3 type		Туре 1	
Compatibility		Supports 2 wire and 3 wire sensors	
Cable	Туре	Shielded	
	Length	Maximum 10 m (33 ft)	
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable	
Maximum frequency		 100 kHz is the maximum frequency for Single-phase 50 kHz is the maximum frequency for 2- phase Duty Rate: 4555% 	
Phase Counting Mode		 Single phase 2 Phase x2 2 Phase x4 2 Phase x2 Reverse 2 Phase x4 Reverse 	
Response time	Marker	1 ms	
	Preload	1 ms	
	Prestrobet	1 ms	
Synchronize output		2 ms	
Min. Pulse Width (Pulse Input)		Counter: 10 µs 10 µs 5 µs 5 µs 5 µs 5 µs 25 µs	
Input paralleling		No	

Digital Outputs

Transistor Output Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the transistor outputs:

Characteristic		Value	
Rated voltage		24 Vdc	
Output range		19.228.8 Vdc	
Output type		Sink/Source	
Rated current		0.3 A/point, 3.0 A/common	
Residual voltage		1.5 Vdc or less for I = 0.1 A	
Delay		Off to on (0.3 A load): 1.1 ms On to off (0.3 A load): 2 ms NOTE: The delay is not including the cable delay.	
Isolation	Method	Photocoupler Isolation	
	Between internal logic	500 Vdc	
Minimum resistor load		80 Ω at 24 Vdc	
Cable length		Non-shielded: 150 m (492 ft)	
Protection against short circuit		No	
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable	
NOTE: Refer to Protecting Outputs from Inductive L additional information on this topic.		oad Damage <i>(see page 34)</i> for	

Pulse Output/PWM Output/High-speed Counter (Synchronize Output) Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the Pulse Output/PWM Output/Highspeed Counter (Synchronize Output):

	Sink/Source		
		Sink/Source	
Rated voltage		24 Vdc	
	19.228.8 Vdc		
ion	Yes		
rent	50 mA/point, 100 mA/com	mon	
out	2 ms		
Between fast outputs and internal logic	10 $M\Omega$ or more		
Between power supply port and protective earth ground (PE) = 500 Vdc	10 MΩ or more		
for I = 0, 1 A	1.5 Vdc or less		
Delay		Off to on (50 mA load): 2.5 ms On to off (50 mA load): 2.5 ms NOTE: The delay is not including the cable delay.	
Minimum load impedance			
Maximum Pulse output frequency			
ency	65 kHz		
Frequency	Accuracy	Duty	
101000 Hz	1%	199%	
1.00120 kHz	5%	595%	
20.00145 kHz	10%	1090%	
45.00165 kHz	15%	1585%	
Duty rate range			
Туре	Shielded, including 24 Vdc power supply		
Length	Maximum 5 m (16 ft)		
Terminal blocks			
	rent put Between fast outputs and internal logic Between power supply port and protective earth ground (PE) = 500 Vdc for I = 0, 1 A ency Frequency 101000 Hz 1.00120 kHz 20.00145 kHz 45.00165 kHz	rent50 mA/point, 100 mA/comput2 msBetween fast outputs and internal logic10 MΩ or moreBetween power supply port and protective earth ground (PE) = 500 Vdc10 MΩ or morefor I = 0, 1 A1.5 Vdc or lessOff to on (50 mA load): 2.5 On to off (50 mA load): 2.5 NOTE: The delay is not incl delay.ency50 KHzency50 KHzFrequencyAccuracy101000 Hz1%1.00120 kHz5%20.00145 kHz10%45.00165 kHz199%TypeShielded, including 24 Vdc	

Analog Inputs and Analog Outputs

Analog Input Characteristics

The table describes the characteristics of the analog inputs:

Characteristic		Voltage input	Current input		
Number of maximum input		2			
Input type		Single-ended	Single-ended		
Input range		-10 10 Vdc/010 Vdc	020 mA/420 mA		
Input impedance		1 M Ω or more	$250 \pm 0.11\%$ Ω		
Sample duration	time	10 ms per channel + 1 scan	time		
Total input system	m transfer time	20 ms + 1 scan time			
Input tolerance	Maximum deviation at 25°C (77°F) without electromagnetic disturbance	± 1% of the full scale			
	Maximum deviation	± 2.5% of the full scale			
Digital resolution	•	13 bits			
Temperature drif	t	± 0.06% of the full scale			
Common mode characteristics		80 db			
Cross talk		60 db			
Non-linearity		± 0.4% of full scale			
Input value of LSB		5 mV	10 μΑ		
Maximum allowed overload (no damages)		± 30 Vdc (less than 5 minutes) ± 15 Vdc (No damage)	± 30 mA dc		
Protection type		Photo coupler between input and internal circuit			
Cable	Туре	Shielded			
Length		Must be less than 3 m for IEC61131-2 conformance. Maximum transmission distance is 10 m.			
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable			
Isolation		External input: Photo-coupler isolation Between channels: Non-isolated			

Temperature Input (Temperature Probes) Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the Temperature Input (Temperature Probes):

Input Characteristic	s	
Input sensor type		Pt100/Pt1000/Ni100/Ni1000
Input temperature range		Pt100/Pt1000: -200600°C (-3281112°F) Ni100/Ni1000: -20200°C (-4392°F)
Measuring current	Pt100/Ni100	1.12 mA ± 3.5%
	Pt1000/Ni1000	0.242 μA ± 3.5%
Input impedance		Typically 10 M Ω
Sample duration time)	10 ms+1 cycle time
Wiring type		2-wire or 3-wire connection configured by software for all inputs
Conversion mode		Sigma delta type
Input filter		Low pass
Resolution temperatu	ure value	0.1°C <i>(0.18°F)</i>
Detection type		Open circuit (detection on each channel)
Input tolerance*	Maximum deviation at 25°C (77°F) without electromagnetic disturbance	± 5°C (41°F)
	Maximum deviation at 2550°C (77122°F)	Pt type: ± 5.6°C (42.08°F) Ni type: ± 5.2°C (41.36°F)
Temperature drift		30 ppm/°C
Digital resolution		16 bits
Rejection in differential mode	50/60 Hz	Typically 60 dB
Common mode rejection		Typically 80 dB
Isolation Method		Photocoupler Isolation
Permitted input signal		±5 Vdc max.
Cable length	Pt100/Ni100	20 Ω or less
	Pt1000/Ni1000	200 Ω or less
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable
Noise resistance - cable		Shielded cable is necessary
* Excluding errors caused by the wiring		

Temperature Input (Thermocouple) Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the Temperature Input (Thermocouple):

Input Characteristics		
Input sensor type		Thermocouple
Input type range ⁽¹⁾		J (-200760°C) (-3281400°F) K (-2401370°C) (-4002498°F) R (01600°C) (322912°F) B (2001800°C) (3923272°F) S (0°C1600°C) (322912°F) T (-200400°C) (-328752°F) E (-200900°C) (-3281652°F) N (-2001300°C) (-3282372°F)
Input impedance		Typically 10 M Ω
Sample duration time)	10 ms+1 cycle time
Conversion mode		Sigma delta type
Digital resolution		16 bits
Input filter		Low pass
Resolution temperatu	ire value	0.1°C <i>(0.18°F)</i> (Type J)
Detection type		Open circuit (detection on each channel)
Input tolerance	Maximum deviation at 25°C (77°F) without electromagnetic disturbance	0.2 % of the full scale, plus standard point of compensation precision at +/- 6°C.
	Maximum deviation	0.28 % of full scale range
Temperature drift		30 ppm/°C
Input tolerance - term compensation	ninal temperature	± 5°C (41°F) after 10 min.
Cold junction comper temperature range (0		Internal cold junction error: +/- 6°C (42.8°F) after operating 45 minutes.
Rejection in differential mode	50/60 Hz	Typically 60 dB
Common mode rejection		Typically 80 dB
Isolation Method		Photocoupler Isolation
Permitted input signal		± 5 Vdc max.
Warm up time		45 minutes
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable
Noise resistance - cable		Shielded cable is necessary
(1) Temperature measurement on PCB at ter		minal block for cold junction compensation.

Analog Output Characteristics

UNINTENDED EQUIPMENT OPERATION

Do not exceed any of the rated values specified in the following tables.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

The table describes the characteristics of the analog outputs:


Characteristic		Voltage Output	Current Output
Maximum number of outputs		2	
Output range		-10 10 Vdc/010 Vdc	020 mA / 420 mA
Load impedance		2 kΩ or more	300 Ω or less
Application load type	e	Resistive load	
Settling time		10 ms	
Total output system	transfer time	10 ms + 1 scan time	
Output tolerance	Maximum deviation at 25°C (77°F) without electromagnetic disturbance	± 1% of the full scale	
	Maximum deviation	\pm 2.5% of the full scale	
Digital resolution		12 bits	
Temperature drift		± 0.06% of the full scale	
Output ripple		± 50 mV	
Cross talk		60 db	
Non-linearity		± 0.5% of the full scale	
Output value of LSB		6 mV	12 μΑ
Protection type		Photo coupler between input and internal circuit	
Output protection		Short circuit protection: Yes Open ciruit protection: Yes	
Output behavior if input power supply is less than the power failed threshold		Set to 0	
Cable	Туре	Shielded	
Length		Must be less than 3 m for IEC61131-2 conformance. Maximum transmission distance is 10 m.	
Terminal blocks		Type: 3.5 mm (0.137 in.) pitch Terminal blocks are removable	
Isolation		External input: Photo-coupler isolation Between channels: Non-isolated	

Internal Circuits


LT-4201TM/4301TM (Modular Type DIO) Internal Circuit

Terminal Blocks (see page 92).


The circuit configuration of I0, I1 is shown as follows:




The circuit configuration from I2 to I19 is shown as follows:




The circuit configuration of Q0 and Q1 is shown as follows: The circuit configuration from Q2 to Q11 is shown as follows: It is source type




The circuit configuration of Q0 and Q1 is shown as follows: It is sink type



It is source type




The circuit configuration from Q2 to Q11 is shown as follows: It is sink type




LT-4201TM/4301TM (Modular Type Analog) Internal Circuit

Terminal Blocks (see page 100).


The circuit configuration of I0, I1 is shown as follows:




The circuit configuration from I2 to I11 is shown as follows:




The circuit configuration of Q0 and Q1 is shown as follows: The circuit configuration from Q2 to Q7 is shown as follows: It is source type




It is source type



The circuit configuration of Q0 and Q1 is shown as follows: The circuit configuration from Q2 to Q7 is shown as follows: It is sink type



It is sink type



Memory and Touch Panel

Memory

The table shows the memory specifications of LT:

Items	Specification	
Application memory ⁽¹⁾	FLASH EPROM 16 MB (Includes screen editing program and extended logic program)	
Logic program area	FLASH EPROM 132 KB ⁽²⁾ (equivalent to 15,000 steps)	
Font area	FLASH EPROM 8 MB (when limit exceeded, uses application memory)	
Data backup	nvSRAM 128 KB	
Variable area	nvSRAM 64 KB	
 (1) Capacity available for user application. (2) Up to 60,000 steps can be converted in software. However, this reduces application memory capacity (for screen data) by 1 MB. 		

Data Back-Up Management

This memory saves data even when the LT is turned OFF. Upon user request, the setting can be changed through software application.

Touch Panel

The table shows the touch-panel specifications of LT:

Items	Specification
Туре	Resistive Film (analog)
Lifetime	1 million touches or more

Maintenance

11

Overview

This chapter explains how to maintain your LT units.

What Is in This Chapter?

This chapter contains the following topics:

Торіс	Page
Regular Cleaning	140
Periodic Check Points	141

Regular Cleaning

Cleaning the Display

NOTICE

EQUIPMENT DAMAGE

- Power off the unit before cleaning it.
- Do not use hard or pointed objects to operate the touch panel since it can damage the panel surface.
- Do not use paint thinner, organic solvents, or a strong acid compound to clean the unit.

Failure to follow these instructions can result in equipment damage.

When the surface or the frame of the display gets dirty, soak a soft cloth in water with a neutral detergent, wring the cloth tightly, and wipe the display.

Periodic Check Points

Operation Environment

Refer to the Environmental Specifications (see page 31).

Electrical Specifications

The input voltage must be within 20.4 to 28.8 Vdc.

Related Items

- Are all power cords and cables connected properly? Are there any loose cables?
- Are all display installation nuts holding the unit securely?



California Proposition 65 Warning—Lead and Lead Compounds Advertencia de la Proposición 65 de California—Plomo y

compuestos de plomo Avertissement concernant la Proposition 65 de Californie— Plomb et composés de plomb

WARNING: This product can expose you to chemicals including lead and lead compounds, which are known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to: www.P65Warnings.ca.gov. ADVERTENCIA: Este producto puede exponerle a químicos incluyendo plomo y compuestos de plomo, que es (son) conocido(s) por el Estado de California como causante(s) de cáncer y defectos de nacimiento u otros daños reproductivos. Para mayor información, visite : www.P65Warnings.ca.gov. AVERTISSEMENT: Ce produit peut vous exposer à des agents chimiques, y compris plomb et composés de plomb, identifiés par l'État de Californie comme pouvant causer le cancer et des malformations congénitales ou autres troubles de l'appareil reproducteur. Pour de plus amples informations, prière de consulter: www.P65Warnings.ca.gov.

All trademarks are the property of Schneider Electric SE, its subsidiaries, and affiliated companies.

Schneider Electric USA, Inc. 800 Federal Street Andover, MA 01810 USA 888-778-2733 www.schneider-electric.us Todas las marcas comerciales son propiedad de Schneider Electric SE, sus filiales y compañías afiliadas.

Importado en México por: Schneider Electric México, S.A. de C.V. Av. Ejercito Nacional No. 904 Col. Palmas, Polanco 11560 México, D.F. 55-5804-5000 www.schneider-electric.com.mx Toutes les marques commerciales sont la propriété de Schneider Electric SE, ses filiales et compagnies affiliées.

Schneider Electric Canada, Inc. 5985 McLaughlin Road Mississauga, ON L5R 1B8 Canada 800-565-6699 www.schneider-electric.ca

