Data sheet

6AV7863-5MA16-2NA0

SIMATIC IFP1500 V2 PRO, 15 multi-touch display (16:9) with 1920x1080 pixel resolution, PRO variant support arm, with operator control, for 24 V DC, display port/DVI interface, can be placed up to 100 m away HDBaseT, USB on the rear side, neutral design



Figure similar

General information	
Product type designation	IFP1500 V2 PRO
Short designation	Flat Panel 15" multi-touch ext.
Display	
Design of display	TFT widescreen display, LED backlighting
Screen diagonal	15.6 in; 15"
Screen diagonal [cm]	39 mm
Display width	344.2 mm
Display height	193.5 mm
On Screen Display (OSD) configuration	No; Adjustable by means of software
Number of colors	16 777 216; 24 bit
Viewing angle	178° x 178°
Resolution (pixels)	
 Image resolution 	1 920 x 1 080
 Horizontal image resolution 	1 920 pixel
 Vertical image resolution 	1 080 pixel
 Pixel size, horizontal 	0.17925 mm
 Pixel size, vertical 	0.17925 mm
General features	
Brightness/contrast	400 cd/m² / 1 000:1
 non-reflective and tempered mineral glass screen 	Yes
Detachable from computer unit	100 m; HDBaseT protocol
Luminance	400 cd/m ²
Backlighting	
Type of backlighting	LED
 MTBF backlighting (at 25 °C) 	50 000 h; At 25°C
Backlight dimmable	Yes; 0-100 %
Control elements	
Control elements	multi-touch screen
Input device	
Integrated mouse cursor control	Yes
Touch operation	
Design as touch screen	Yes; Projective-capacitive
Design as multi-touch screen	Yes; Projective-capacitive
Monitor keyboard	Yes
nstallation type/mounting	
Design	Support arm mounting
Front mounting	No
Support arm mounting	Yes; Suitable for support arm and extension components (please refer to

	manual
Stand mounting	manual)
Stand mounting	No Voc: With VESA adapter set
VESA mounting Mounting in portrait format possible	Yes; With VESA adapter set
Mounting in portrait format possible maximum permitted forward tilt angle from vertical	No 45°
maximum permitted forward tilt angle from vertical	45°
Supply voltage	
Type of supply voltage	DC
Rated value (DC)	24 V; PELV / SELV floating
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	1A
Current consumption, max.	1.3 A
Starting current inrush I²t	0.5 A²·s
Power loss	
Power loss, typ.	24 W
Power loss, max.	30 W
Interfaces	
Number of USB interfaces	2; USB 2.0 type A
USB on the rear	Yes; 2x onboard
Connection for keyboard/mouse	USB
Video interfaces	
DisplayPort	Yes; Display port V1.2
Touch interfaces	
• USB	Yes
Degree and class of protection	
IP (at the front)	IP65
IP (rear)	IP65
NEMA (front)	
 Enclosure Type 4 at the front 	Yes
Enclosure Type 4 at the front Standards, approvals, certificates	Yes
	Yes Yes
Standards, approvals, certificates	
Standards, approvals, certificates CE mark	Yes
Standards, approvals, certificates CE mark cULus	Yes Yes; Corresponds to UL 508
Standards, approvals, certificates CE mark cULus FM approval	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK)	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes No
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min.	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes No
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max.	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes No
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min.	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max.	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max.	Yes Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IFCEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max. Relative humidity	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yos No 0 °C 45 °C -20 °C 60 °C 3 500 m
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max. Relative humidity • Operation, max.	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max. Relative humidity • Operation, max. Vibrations	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Your Carresponds to UL 508 Yes Yes Yes Your Carresponds to UL 508 Yes Yes Yes Yes Your Carresponds to UL 508 Yes; Class I Div. 2 Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max. Relative humidity • Operation, max. Vibrations • Vibration load in operation	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yos Yos Yos Yos Yos Yos Yos Yos Yos Yo
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max. Relative humidity • Operation, max. Vibrations • Vibration load in operation • Vibration load during transport/storage	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yes Your Carresponds to UL 508 Yes Yes Yes Your Carresponds to UL 508 Yes Yes Yes Yes Your Carresponds to UL 508 Yes; Class I Div. 2 Yes
Standards, approvals, certificates CE mark cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Ambient conditions Ambient temperature during operation • min. • max. Ambient temperature during storage/transportation • min. • max. Altitude during operation relating to sea level • Installation altitude above sea level, max. Relative humidity • Operation, max. Vibrations • Vibration load in operation	Yes; Corresponds to UL 508 Yes; Class I Div. 2 Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes Yes Yes Yes Yos Yos Yos Yos Yos Yos Yos Yos Yos Yo

 shock acceleration during storage/transport 	15 gn
Mechanics/material	
Enclosure material (front)	With neutral design
Aluminum	Yes
 Aluminum casting 	Yes
Glass	Yes; at front
Enclosure material (rear)	aluminum
Dimensions	
Width	396 mm
Height	255 mm
Depth	162.8 mm
Width of the housing front	396 mm
Height of housing front	255 mm; Without basic adapter
Weights	
Weight (without packaging)	5.9 kg
Weight (with packaging)	6.8 kg

last modified: 3/12/2024 🖸