









Technical specifications:

acceptable. 1. All welded points should be well welded. Any defect on small holes or leaks is not

- 2. The inner tubes should be cleaned without impurities before bending
- 3. All connectors must equipped with sealing cap
- 4. Design Pressre: refrigerant side 4.2MPa, water side 1.0MPa;
- 6. Any non-indicated dimensions and tolerances are subject to GB/T1804 V degree. 5. Fill 0.05-0.12Mpa nitrogen gas at refrigerant side, the pressure is maintained;
- 7. The shell sealing area needs to be cooling when welding refrigerant connectors.

Ь.			_	_			_
Process	Approve	Check	Design	Mark			
SSE	ove	_	3	No.			
				Mark No. Modify documents No. Sign Date			
Date		Authorize	Standard	uments			
		orize	dard	No. s			
				sign			
				Date			
Total Page			Drawing mark		Outer Shell:Steel	Inner tube:Titanium (Inner thread	Shell Pipe Heat Exchanger
					tee C	anlum (	teat I
Page			Welght			Inner the	Exchai
			Scale			read )	nger
CSSF3674000			SS-0360GSTi-F2 530/290/410/Ø22. 2/Ø14/62/ZJ				HANGZHOU SHENSHI ENERGI CUNSERVALLUN TECHNOLOGY CO., LTD